

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.023	=	0.079	MGD								Daily	INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD								05/WK - Five Per Week	IN - INSTAN
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1			=	2.8	19 - mg/L	21/30 - 21 Per Month	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

The BOD sample from 5-12-15 was given a result of Laboratory Error (LE) due to no GGA standard being included in the batch. The BOD sample from 5-27-15 was given a result of LE due to insufficient depletion in all seed control samples

Attachments

No attachments.

Report Last Saved By**AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time: 2015-08-07 11:59 (Time Zone: -05:00)