

DMR Copy of Record

Permit**Permit #:** TX0046981**Major:** ☒**Permitted Feature:** 001
External Outfall**Permittee:** AUSTIN, CITY OF (WALNUT CREEK)**Permittee Address:** PO BOX 1088
AUSTIN, TX 78767**Facility:** CITY OF AUSTIN(WALNUT CREEK)**Facility Location:** 7113 EAST FM 969
AUSTIN, TX 787678859**Discharge:** **001-A**
DOMESTIC FACILITY-OUTFALL 001**Report Dates & Status****Monitoring Period:** From 04/01/15 to 04/30/15**DMR Due Date:** 05/20/15**Status:** NetDMR Validated & Complete**Considerations for Form Completion****Principal Executive Officer****First Name:** Greg**Title:** Director**Telephone:** 512-972-0101**Last Name:** Meszaros**No Data Indicator (NODI)****Form NODI:** --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.1					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.5			=	7.1	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1308			26 - lb/d			=	2.9	=	7.4	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	370			26 - lb/d			<	0.8	=	4.6	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	53.7	=	59.2	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2015-05-13 19:31 (Time Zone: -05:00)