

DMR Copy of Record

Permit

Permit #: TX0046981

Major: ☒Permitted Feature: 001
External Outfall

Permittee: AUSTIN, CITY OF (WALNUT CREEK)

Permittee Address: PO BOX 1088
AUSTIN, TX 78767

Facility: CITY OF AUSTIN(WALNUT CREEK)

Facility Location: 7113 EAST FM 969
AUSTIN, TX 787678859Discharge: 001-A
DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period: From 08/01/15 to 08/31/15

DMR Due Date: 09/20/15

Status: NetDMR Validated & Complete

Considerations for Form Completion

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	6.2					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.5			=	7.4	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	821			26 - lb/d			<	2.1	=	15.5	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	263			26 - lb/d			<	0.7	=	7.2	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	47.5	=	52.3	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value															

					NODI														
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	46781	78 - gal/min								99/99 - Continuous	TM - TOTALZ
					Permit Req.			<=	114583 2HR PEAK	78 - gal/min								99/99 - Continuous	TM - TOTALZ
					Value NODI														
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	59.4			03 - MGD								99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	75 ANNUL AVG			03 - MGD								99/99 - Continuous	TM - TOTALZ
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.02	19 - mg/L			01/01 - Daily	GR - GRAB
					Permit Req.								<	.1 INST MAX	19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1				19 - mg/L			01/01 - Daily	GR - GRAB
					Permit Req.					>=	1 MINIMUM				19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample								<	2	=	11	30 - MPN/100mL	05/WK - Five Per Week	GR - GRAB
					Permit Req.								<=	126 DAILY AV	<=	399 DAILY MX	3Z - CFU/100mL	05/WK - Five Per Week	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	797			26 - lb/d			<	2	=	2.4	19 - mg/L	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	6255 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

Ecoli: Units reported in MPN/100 mL, not CFU/100 mL. CBOD sample from 8/9/15 given a result of Laboratory Error (LE) due to a GGA standard failure. NH3-N sample from 8/10/15 given a result of Sampling Error (SE) due to the pH of the sample being out of range upon receipt. CBOD sample from 8/11/15 given a result of LE due to a GGA standard failure. Ecoli sample from 8/13/15 given a result of SE due to the fact it did not reflect a representative sample.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov
Name: Jane Burazer
E-Mail: jane.burazer@austintexas.gov

Date/Time: 2015-09-15 18:38 (Time Zone: -05:00)