

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.26	=	0.4	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1			=	3.8	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		01/01 - Daily	GR - GRAB	
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							=	2	=	5	30 - MPN/100mL	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.							<=	126 DAILY AV	<=	399 DAILY MX	3Z - CFU/100mL		02/30 - Twice Per Month	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	4.4			26 - lb/d		<	3.4	=	5	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

Ecoli: Units reported in MPN/100 mL, not CFU/100 mL.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Date/Time:

2016-02-16 12:27 (Time Zone: -06:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov