

## DMR Copy of Record

### Permit

<b>Permit #:</b>	<b>TX0071889</b>	<b>Permittee:</b>	AUSTIN, CITY OF (S AUSTIN REG)	<b>Facility:</b>	SOUTH AUSTIN REGIONAL WWTF
<b>Major:</b>	<input checked="" type="checkbox"/>	<b>Permittee Address:</b>	PO BOX 1088 AUSTIN, TX 78767	<b>Facility Location:</b>	13009 FALWELL LANE AUSTIN, TX 78767
<b>Permitted Feature:</b>	001 External Outfall	<b>Discharge:</b>	<b>001-Y</b> DOMESTIC FACILITY - 001		

### Report Dates & Status

<b>Monitoring Period:</b>	<b>From 01/01/16 to 12/31/16</b>	<b>DMR Due Date:</b>	<b>01/20/17</b>	<b>Status:</b>	<b>NetDMR Validated &amp; Complete</b>
---------------------------	----------------------------------	----------------------	-----------------	----------------	--

### Considerations for Form Completion

THE ANNUAL AVERAGE IS THE SUM OF THE MONTHLY AVERAGES DIVIDED BY 12 BASED ON A CALENDAR YEAR. THE RESULTS SHALL BE SUBMITTED TO THE TCEQ WATER QUALITY COMPLIANCE MONITORING TEAM OF THE ENFORCEMENT DIVISION OF THE TCEQ IN JANUARY OF EACH YEAR

### Principal Executive Officer

<b>First Name:</b>	Greg	<b>Title:</b>	Director, Austin Water	<b>Telephone:</b>	512-972-0101
<b>Last Name:</b>	Meszaros				

### No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00530	Solids, total suspended	Y - Effluent Gross (Supplementary)	0	--	Sample							=	2.5			19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.							<=	5 ANNL AVG			19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI														
00610	Nitrogen, ammonia total [as N]	Y - Effluent Gross (Supplementary)	0	--	Sample							<	0.5			19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.							<=	2 ANNL AVG			19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	Y - Effluent Gross (Supplementary)	0	--	Sample							<	2.4			19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.							<=	5 ANNL AVG			19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI														

### Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

***Edit Check Errors***

*No errors.*

***Comments***

***Attachments***

*No attachments.*

***Report Last Saved By***

***AUSTIN, CITY OF (S AUSTIN REG)***

User: dana.white@austintexas.gov

Name: Dana White

E-Mail: dana.white@austintexas.gov

Date/Time:

2017-01-18 12:32 (Time Zone: -06:00)