

Permit

Major:

Facility:	THOROUGHbred FARMS WWTP
Facility Location:	8250 CITATION AVE, 2400F E. FMR 973 AUSTIN, TX 787670000

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Status: NetDMR Validated & Complete

Telephone: 512-972-0101

Form NODI: --

[illegible]

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample														05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L			
					Value NODI							C - No Discharge				C - No Discharge				

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Thoroughbred Farms WWTP did not discharge at all in the month of February 2016. The plant was damaged in the flood event of 10/30/15. Utilizing pump and haul. Hauling effluent to Walnut Creek WWTP (TX0046981).

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time: 2016-03-11 11:25 (Time Zone: -06:00)