

## DMR Copy of Record

### Permit

Permit #: TX0067466

Major:

Permittee: AUSTIN, CITY OF  
 Permittee Address: 625 E 10TH ST STE 800  
 AUSTIN, TX 78701

Facility: THOROUGHbred FARMS WWTP  
 Facility Location: 8250 CITATION AVE, 2400F E. FMR 973  
 AUSTIN, TX 787670000

Permitted Feature: 001  
 External Outfall

Discharge: 001-A  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: From 06/01/16 to 06/30/16

DMR Due Date: 07/20/16

Status: NetDMR Validated & Complete

### Considerations for Form Completion

### Principal Executive Officer

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

### No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample															
					Permit Req.					>=	2 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample															
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI		C - No Discharge							C - No Discharge		C - No Discharge				
00400	pH	1 - Effluent Gross	0	--	Sample															
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI												C - No Discharge			
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample															
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI		C - No Discharge							C - No Discharge		C - No Discharge				
50050	Flow, in conduit or thru treatment	1 - Effluent Gross	0	--	Sample															
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD										05/WK - Five Per Week

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
	plant																	
					Value NODI	C - No Discharge		C - No Discharge										
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample													
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Value NODI						C - No Discharge				C - No Discharge			

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

Plant did not discharge 6-1-16 to 6-30-16. Plant damaged in the floods on 10-30-15 and again on 5-27-16. Flows were pumped and hauled to the Walnut Creek WWTP (TX0046981)

**Attachments**

No attachments.

**Report Last Saved By**

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2016-07-13 12:32 (Time Zone: -05:00)