

DMR Copy of Record

Permit

Permit #: TX0067466

Major: ☐

Permittee: AUSTIN, CITY OF
Permittee Address: 625 E 10TH ST STE 800
AUSTIN, TX 78701

Facility: THOROUGHbred FARMS WWTP
Facility Location: 8250 CITATION AVE,2400F E. FMR 973
AUSTIN, TX 787670000

Permitted Feature: 001
External Outfall

Discharge: 001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 05/01/16 to 05/31/16

DMR Due Date: 06/20/16

Status: NetDMR Validated & Complete

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample													01/07 - Weekly	GR - GRAB
					Permit Req.						> =	2 MO MIN				19 - mg/L			
					Value NODI							C - No Discharge							
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample													01/07 - Weekly	GR - GRAB
					Permit Req.	< =	11 DAILY AV			26 - lb/d			< =	20 DAILY AV	< =	65 SINGGRAB	19 - mg/L		
					Value NODI		C - No Discharge						C - No Discharge		C - No Discharge				
00400	pH	1 - Effluent Gross	0	--	Sample													01/30 - Monthly	GR - GRAB
					Permit Req.						> =	6 MINIMUM			< =	9 MAXIMUM	12 - SU		
					Value NODI							C - No Discharge				C - No Discharge			
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample													01/07 - Weekly	GR - GRAB
					Permit Req.	< =	11 DAILY AV			26 - lb/d			< =	20 DAILY AV	< =	65 SINGGRAB	19 - mg/L		
					Value NODI		C - No Discharge							C - No Discharge		C - No Discharge			
50050	Flow, in conduit or thru treatment	1 - Effluent Gross	0	--	Sample													05/WK - Five Per Week	IN - INSTAN
					Permit Req.	< =	.065 DAILY AV		Req Mon DAILY MX	03 - MGD									

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
	plant																		
						Value NODI	C - No Discharge		C - No Discharge										
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample													05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX			
					Value NODI							C - No Discharge				C - No Discharge			

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Plant did not discharge 5-1-16 to 5-31-16. Plant damaged in the floods on 10-30-16 and again on 5-27-17. Flows were pumped and hauled to the Walnut Creek WWTP (TX0046981)

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov
Name: Jane Burazer
E-Mail: jane.burazer@austintexas.gov

Date/Time: 2016-06-13 14:18 (Time Zone: -05:00)