



# Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087

## MONTHLY EFFLUENT REPORT

<b>WQ0010543-012</b>
PERMIT NUMBER

<b>01</b>
SET

<b>16</b>	<b>5</b>
YEAR	MO

<b>19743</b>
EID

This report to be used for OTFL 800 RECLAIMED WATER TYPE I

Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition		No. Ex	Frequency of Analysis	Sample Type
	Value	Units			
000085342 TRANSFER DAYS/MON	Permitted				
	Reported	31	DAY	0	NA
800821024 CBOD5 DLY. AVG.	Permitted	5.000	mg/L		GRAB PKLOAD
	Reported	<2.2	mg/L	0	GRAB PKLOAD
820796624 Turbidity 30DAYAVG	Permitted	3.000	NTU		GRAB PKLOAD
	Reported	1.68	NTU	0	GRAB PKLOAD
316403730 E. coli IND. GRAB	Permitted	75.000	MPN/100 mL		GRAB PKLOAD
	Reported	2	MPN/100 mL	0	GRAB PKLOAD
316403724 E. coli DLY AVG	Permitted	20.000	MPN/100 mL		GRAB PKLOAD
	Reported	<1	MPN/100 mL	0	GRAB PKLOAD
500507124 FLOW DLY. AVG.	Permitted		MGD		CONT
	Reported	2.35	MGD	0	CONT
NUMBER OF OPERATOR CERTIFICATE	Permitted		NUMBER		01
	Reported	WW0011708	NUMBER	0	01
EXPIRATION OF OPERATOR CERTIFICATE	Permitted		DATE		01
	Reported	5/12/2018	DATE	0	01
CLASS OF OPERATOR CERTIFICATE	Permitted		LETTER		01
	Reported	B	LETTER	0	01

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
Randall Swenson	<i>Randall Swenson</i>	6	8	16
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Greg Meszaros, Director	<i>Greg Meszaros</i>	6	8	16
Telephone Number		512	972-0101	
		Area code	Number	

Texas Commission on Environmental Quality



# Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087

## MONTHLY EFFLUENT REPORT

<b>WQ0010543-012</b>
PERMIT NUMBER

<b>01</b>
SET

<b>16</b>	<b>5</b>
YEAR	MO

<b>19742</b>
EID

This report to be used for OTFL 900 RECLAIMED WATER TYPE II

Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition		No. Ex	Frequency of Analysis	Sample Type
	Value	Units			
000085342 TRANSFER DAYS/MON	Permitted				
	Reported				
800821024 CBOD5 DLY. AVG.	Permitted				
	Reported				
316403730 E. coli IND. GRAB	Permitted				
	Reported				
316403724 E. coli DLY. AVG.	Permitted				
	Reported				
500507124 FLOW DLY. AVG.	Permitted				
	Reported				
NUMBER OF OPERATOR CERTIFICATE	Permitted				
	Reported				
EXPIRATION OF OPERATOR CERTIFICATE	Permitted				
	Reported				
CLASS OF OPERATOR CERTIFICATE	Permitted				
	Reported				

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

Reclaim water is Type I Only.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
Randall Swenson	<i>Randall Swenson</i>	6	8	16
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Greg Meszaros, Director	<i>Greg Meszaros</i>	6	8	16
Telephone Number		512	972-0101	
		Area code	Number	

Texas Commission on Environmental Quality



# Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087  
MONTHLY EFFLUENT REPORT

<b>WQ0010543-012</b>
PERMIT NUMBER

<b>01</b>
SET

<b>16</b>	<b>5</b>
YEAR	MO

<b>19744</b>
EID

This report to be used for COMBINED OTFL 001 AND RECLAIMED WATER

Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition			No. Ex	Frequency of Analysis	Sample Type
		Value	Units			
500507124 FLOW DLY. AVG.	Permitted		MGD		CONT	CONT
	Reported	59.8	MGD	0	CONT	CONT
NUMBER OF OPERATOR CERTIFICATE	Permitted		NUMBER		01	NA
	Reported	WW0011708	NUMBER	0	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	Permitted		DATE		01	NA
	Reported	5/12/2018	DATE	0	01	NA
CLASS OF OPERATOR CERTIFICATE	Permitted		LETTER		01	NA
	Reported	B	LETTER	0	01	NA
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
Randall Swenson		6	8	16
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Greg Meszaros, Director		6	8	16
Telephone Number		512	972-0101	
		Area code	Number	

Texas Commission on Environmental Quality



# Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087

## MONTHLY EFFLUENT REPORT

<b>WQ0010543-011</b>
PERMIT NUMBER

<b>01</b>
SET

<b>16</b>	<b>5</b>
YEAR	MO

<b>15650</b>
EID

This report to be used for **OTFL 800 RECLAIMED WATER TYPE I**

Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition			No. Ex	Frequency of Analysis	Sample Type
		Value	Units			
<b>316403724</b> E. coli DLY. AVG.	Permitted	<b>20.000</b>	MPN/100 mL		<b>2/week</b>	GRAB PKLOAD
	Reported	<1	MPN/100 mL	0	2/week	GRAB PKLOAD
<b>316403730</b> E. coli IND. GRAB	Permitted	<b>75.000</b>	MPN/100 mL		<b>2/week</b>	GRAB PKLOAD
	Reported	<2	MPN/100 mL	1	2/week	GRAB PKLOAD
<b>500507124</b> FLOW DLY. AVG.	Permitted		MGD		<b>CONT</b>	CONT
	Reported	0.45	MGD	0	CONT	CONT
<b>800821024</b> CBOD5 DLY. AVG.	Permitted	<b>5.000</b>	mg/L		<b>2/week</b>	GRAB PKLOAD
	Reported	<2.1	mg/L	0	2/week	GRAB PKLOAD
<b>820796624</b> TURBIDITY 30DAYAVG	Permitted	<b>3.000</b>	NTU		<b>2/week</b>	GRAB PKLOAD
	Reported	2.39	NTU	0	2/week	GRAB PKLOAD
<b>CLASS OF OPERATOR CERTIFICATE</b>	Permitted		NUMBER		<b>01</b>	NA
	Reported	WW0038287	NUMBER	0	01	NA
<b>NUMBER OF OPERATOR CERTIFICATE</b>	Permitted		DATE		<b>01</b>	NA
	Reported	11/12/2018	DATE	0	01	NA
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	Permitted		LETTER		<b>01</b>	NA
	Reported	A	LETTER	0	01	NA
<b>000085342</b> TRANSFER DAYS/MON	Permitted					
	Reported	31	DAY	0	NA	NA

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

Only one sample collected for E. coli (316403730) for the week of 05/15/16 through 05/21/16.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
James Bennett		6	8	16
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Greg Meszaros, Director		6	8	16
Telephone Number		512	972-0101	
		Area code	Number	

Texas Commission on Environmental Quality



# Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087

## MONTHLY EFFLUENT REPORT

<b>WQ0010543-011</b>
PERMIT NUMBER

<b>01</b>
SET

<b>16</b>	<b>5</b>
YEAR	MO

<b>15651</b>
EID

This report to be used for OTFL 900 RECLAIMED WATER TYPE II

Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition		No. Ex	Frequency of Analysis	Sample Type
	Value	Units			
000085342 TRANSFER DAYS/MON	Permitted				
	Reported				
316403724 E. coli DLY. AVG.	Permitted				
	Reported				
316403730 E. coli IND. GRAB	Permitted				
	Reported				
500507124 FLOW DLY. AVG.	Permitted				
	Reported				
800821024 CBOD5 DLY. AVG.	Permitted				
	Reported				
NUMBER OF OPERATOR CERTIFICATE	Permitted				
	Reported				
EXPIRATION OF OPERATOR CERTIFICATE	Permitted				
	Reported				
CLASS OF OPERATOR CERTIFICATE	Permitted				
	Reported				

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

Reclaim water is Type I Only.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
James Bennett		6	8	16
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Greg Meszaros, Director		6	8	16
Telephone Number		512	972-0101	
		Area code	Number	

Texas Commission on Environmental Quality



# Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087  
MONTHLY EFFLUENT REPORT

<b>WQ0010543-011</b>
PERMIT NUMBER

<b>01</b>
SET

<b>16</b>	<b>5</b>
YEAR	MO

<b>15652</b>
EID

This report to be used for COMBINED OUTFALLS 001 AND RECLAIMED WATER  
Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition			No. Ex	Frequency of Analysis	Sample Type
		Value	Units			
500507124 FLOW DLY. AVG.	Permitted		MGD		CONT	CONT
	Reported	70.0	MGD	0	CONT	CONT
NUMBER OF OPERATOR CERTIFICATE	Permitted		NUMBER		01	NA
	Reported	WW0038287	NUMBER	0	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	Permitted		DATE		01	NA
	Reported	11/12/2018	DATE	0	01	NA
CLASS OF OPERATOR CERTIFICATE	Permitted		LETTER		01	NA
	Reported	A	LETTER	0	01	NA
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
James Bennett		6	8	16
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Greg Meszaros, Director		6	8	16
Telephone Number		512	972-0101	
		Area code	Number	

Texas Commission on Environmental Quality