

DMR Copy of Record

Permit

Permit #: TX0067466

Major:

Permittee: AUSTIN, CITY OF
 Permittee Address: 625 E 10TH ST STE 800
 AUSTIN, TX 78701

Facility: THOROUGHbred FARMS WWTP
 Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
 AUSTIN, TX 787670000

Permitted Feature: 001
 External Outfall

Discharge: 001-A
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 05/01/17 to 05/31/17

DMR Due Date: 06/20/17

Status: NetDMR Validated & Complete

Considerations for Form Completion

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units		
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	5.8					19 - mg/L	0	16/30 - 16 Per Month	GR - GRAB	
					Permit Req.						>=	2 MO MIN							19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI																
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.2			26 - lb/d			<	2	=	2.2	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.1			=	7.9	12 - SU	0	20/30 - Twenty Per Month	GR - GRAB	
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB	
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.6			26 - lb/d			=	5.3	=	6	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	11 DAILY			26 - lb/d			<=	20 DAILY	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
						AV					AV							
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.018	=	0.041	03 - MGD						0	01/01 - Daily	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD							05/WK - Five Per Week	IN - INSTAN
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.1		=	1.9	19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: ayman.benyamin@austintexas.gov

Name: Ayman Benyamin

E-Mail: ayman.benyamin@austintexas.gov

Date/Time: 2017-06-16 10:47 (Time Zone: -05:00)