



Austin Water Utility

CITY OF AUSTIN WATER QUALITY SUMMARY 3rd Quarter 2018

Average Results for Samples Collected July 1, 2018 to September 30, 2018										
CONSTITUENT (mg/L)	DWTP	UWTP	WTP4	DWTP	UWTP	WTP4	SDWA Tap			
	Raw	Raw	Raw	Tap	Tap	Tap	MCL/[SMCL]			
Total Ammonia (as N)	---	---	---	0.52		0.55		0.54		
Free Ammonia (as N)	<0.05	<0.05	<0.05	0.06		0.07		0.08		
Calcium	42	42	37	10		12		9		
Chloramines	---	---	---	2.80		2.69		2.74		
Fluoride	0.21	0.21	0.21	0.76		0.63		0.64		4/[2]
Magnesium	19	19	19	16		13		15		
Sulfate	23.6	23.1	24.0	27.0		30.6		34.8		[250]
Total Phosphate	<0.05	<0.05	<0.05	0.90		0.86		0.90		
Total Hardness (as CaCO ₃)	182	182	173	90		84		84		
pH (units)	8.0	7.9	8.3	9.6		9.6		9.7		>7.0]
Conductivity (umhos/cm)	447	446	436	290		281		319		
Total Alkalinity (as CaCO ₃)	161	161	153	66		60		65		
Phenol Alkalinity (as CaCO ₃)	0	0	1	19		17		18		
Total Solids	236	231	226	145		140		155		[500]
Threshold Odor (TON)	4	4	4	0		0		0		[3]
Total Organic Carbon	3.51	3.42	3.50	2.66		2.44		2.41		
Turbidity (NTU)	1.87	2.17	0.74	0.05		0.02		0.03		0.3
Silica	8.7	8.7	6.6	8.2		7.3		5.7		
UV254 (cm ⁻¹)	0.064	0.061	0.053	0.052		0.047		0.043		
Total Coliform (Col/100ml)	21	4	3	<1		<1		<1		
E.Coli (Col/100ml)	3	1	<1	<1		<1		<1		

< set of averaged measurements contains results that are less than the method detection limit

Parameters listed below were collected and analyzed by TCEQ Contractors for compliance with the Safe Drinking Water Act.										
CONSTITUENT (mg/L)	DWTP	UWTP	WTP4	Central	Detection	South	Detection	North	Detection	SDWA Tap
	Raw	Raw	Raw	Tap	Limit	Tap	Limit	Tap	Limit	MCL/[SMCL] in mg/L
Disinfection By Products, Collected On:				8/2/2018		8/2/2018		8/2/2018		
Haloacetic Acids (HAA5)	&	&	&	0.0111		0.0095		0.0121		0.060
Trihalomethane	&	&	&	0.0319		0.0251		0.0414		0.080
CONSTITUENT (mg/L)	DWTP	UWTP	WTP4	DWTP	Detection	UWTP	Detection	WTP4	Detection	SDWA Tap
	Raw	Raw	Raw	Tap	Limit	Tap	Limit	Tap	Limit	MCL/[SMCL] in mg/L
Pesticides, Collected On:				8/2/2018		2/6/2018		2/6/2018		
Endrin	&	&	&	ND	0.00001	ND	0.00001	ND	0.00001	0.002
Lindane	&	&	&	ND	0.00002	ND	0.00002	ND	0.00002	0.0002
Methoxychlor	&	&	&	ND	0.0001	ND	0.0001	ND	0.0001	0.04
Inorganics, Collected On:				8/2/2018		2/6/2018		2/6/2018		
Chloride	&	&	&	34		35		39		[250]
Sodium	&	&	&	18.4		18.9		24.1		---
Metals, Collected On:				8/2/2018		2/6/2018		2/6/2018		
Aluminum	&	&	&	ND	0.0200	ND	0.0200	N/A	0.0200	[0.05 - 0.2]
Arsenic	&	&	&	ND	0.0020	ND	0.0020	N/A	0.0020	0.01
Barium	&	&	&	0.0104		0.0102		0.012		2
Cadmium	&	&	&	ND	0.0010	ND	0.0010	N/A	0.0010	0.005
Chromium	&	&	&	ND	0.0100	ND	0.0100	N/A	0.0100	0.1
Copper	&	&	&	ND	0.0020	ND	0.0020	0.0086	0.0020	1.3 **
Iron	&	&	&	0.030	0.010	0.017	0.010	0.021	0.010	[0.3]
Lead	&	&	&	ND	0.0010	ND	0.0010	N/A	0.0010	0.015 **
Manganese	&	&	&	ND	0.0010	ND	0.0010	N/A	0.0010	[0.05]
Mercury	&	&	&	ND	0.00040	ND	0.00040	N/A	0.00040	0.002
Nickel	&	&	&	ND	0.0010	ND	0.0010	N/A	0.0010	[0.10]
Selenium	&	&	&	ND	0.0030	ND	0.0030	N/A	0.0030	0.05
Silver	&	&	&	ND	0.0100	ND	0.0100	N/A	0.0100	[0.1]
Antimony	&	&	&	ND	0.0010	ND	0.0010	N/A	0.0010	0.006
Beryllium	&	&	&	ND	0.00080	ND	0.00080	N/A	0.00080	0.004
Thallium	&	&	&	ND	0.00040	ND	0.00040	N/A	0.00040	0.002
Zinc	&	&	&	ND	0.0050	ND	0.0050	N/A	0.0050	[5.0]

SDWA MCL = Safe Drinking Water Act Maximum Contaminant Level

SMCL = Secondary Maximum Contaminant Level standard recommended by TCEQ for aesthetic quality

** = Action Levels

ND = Indicates levels are below detection limits of the instrumentation or method

& = No data available

col/100ml = Colonies per 100 milliliters

mg/L = milligrams per liter