

Drinking Water Quality Report
Date Range: 01-SEP-2010 to 30-SEP-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.6
			MAX	10.0	MAX	9.8
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	52	AVG	51
			MAX	65	MAX	70
			MIN	36	MIN	31
Total Hardness	MG/L	SM 2340 C	AVG	84	AVG	85
			MAX	94	MAX	98
			MIN	71	MIN	77
Total Solids	MG/L	SM 2540 B	AVG	174	AVG	182
			MAX	202	MAX	191
			MIN	160	MIN	173
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.55	AVG	2.27
			MAX	2.75	MAX	2.55
			MIN	2.18	MIN	1.82
Sulfate	MG/L	SM 4500-SO4 E	AVG	29.9	AVG	26.8
			MAX	30.4	MAX	31.8
			MIN	29.2	MIN	21.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	3.08	AVG	2.96
			MAX	3.41	MAX	3.33
			MIN	2.52	MIN	2.26
Conductivity	UMHOS/cm	SM 2510 B	AVG	253	AVG	250
			MAX	254	MAX	250
			MIN	252	MIN	249
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	69.7	AVG	63.8
			MAX	122.0	MAX	85.8
			MIN	37.4	MIN	26.2
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.05
			MAX	0.20	MAX	0.59
			MIN	0.02	MIN	0.02