

Draft Drinking Water Quality Report
Date Range: 01-DEC-2011 to 31-DEC-2011

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.5	MIN	9.3
Total Alkalinity	MG/L	SM 2320 B	AVG	80	AVG	78
			MAX	87	MAX	84
			MIN	71	MIN	72
Total Hardness	MG/L	SM 2340 C	AVG	112	AVG	110
			MAX	120	MAX	116
			MIN	106	MIN	104
Total Solids	MG/L	SM 2540 B	AVG	194	AVG	185
			MAX	210	MAX	196
			MIN	176	MIN	172
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.50
			MAX	3.00	MAX	2.50
			MIN	2.45	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	40.6	AVG	32.7
			MAX	41.1	MAX	32.7
			MIN	40.0	MIN	32.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.71	AVG	2.61
			MAX	2.82	MAX	2.84
			MIN	2.55	MIN	2.33
Conductivity	UMHOS/cm	SM 2510 B	AVG	326	AVG	320
			MAX	326	MAX	320
			MIN	325	MIN	320
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	32.3	AVG	35.5
			MAX	38.7	MAX	37.0
			MIN	23.3	MIN	34.5
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.06
			MAX	0.16	MAX	0.08
			MIN	0.03	MIN	0.03