

Drinking Water Quality Report
Date Range: 01-FEB-2011 to 28-FEB-2011

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	78	AVG	74
			MAX	93	MAX	79
			MIN	70	MIN	69
Total Hardness	MG/L	SM 2340 C	AVG	108	AVG	103
			MAX	122	MAX	113
			MIN	99	MIN	96
Total Solids	MG/L	SM 2540 B	AVG	176	AVG	170
			MAX	194	MAX	192
			MIN	158	MIN	146
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.65	AVG	2.44
			MAX	2.88	MAX	2.52
			MIN	1.78	MIN	2.29
Sulfate	MG/L	SM 4500-SO4 E	AVG	37.9	AVG	36.0
			MAX	42.7	MAX	36.8
			MIN	32.9	MIN	34.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.65	AVG	2.49
			MAX	2.74	MAX	2.62
			MIN	2.57	MIN	2.39
Conductivity	UMHOS/cm	SM 2510 B	AVG	320	AVG	307
			MAX	339	MAX	314
			MIN	304	MIN	300
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	29.8	AVG	28.1
			MAX	38.8	MAX	31.7
			MIN	21.9	MIN	25.9
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.05
			MAX	0.11	MAX	0.08
			MIN	0.05	MIN	0.03