

Draft Drinking Water Quality Report  
Date Range: 01-SEP-2011 to 30-SEP-2011

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.7
			MAX	9.9	MAX	9.9
			MIN	9.6	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	73	AVG	69
			MAX	75	MAX	75
			MIN	69	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	97	AVG	95
			MAX	100	MAX	99
			MIN	93	MIN	86
Total Solids	MG/L	SM 2540 B	AVG	182	AVG	166
			MAX	190	MAX	184
			MIN	162	MIN	148
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.59	AVG	2.50
			MAX	2.70	MAX	2.60
			MIN	2.45	MIN	2.25
Sulfate	MG/L	SM 4500-SO4 E	AVG	29.9	AVG	24.9
			MAX	30.4	MAX	24.9
			MIN	29.3	MIN	24.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.54	AVG	2.37
			MAX	2.64	MAX	2.43
			MIN	2.41	MIN	2.26
Conductivity	UMHOS/cm	SM 2510 B	AVG	314	AVG	290
			MAX	316	MAX	290
			MIN	312	MIN	290
*Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	36.8	AVG	35.5
			MAX	37.0	MAX	35.5
			MIN	36.7	MIN	35.5
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03
			MAX	0.20	MAX	0.07
			MIN	0.05	MIN	0.02

\*THM results do not include all data points for the month. Please check back for updated results.