

Drinking Water Quality Report
Date Range: 01-FEB-2012 to 29-FEB-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	9.8
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	66	AVG	69
			MAX	72	MAX	74
			MIN	60	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	109	AVG	112
			MAX	112	MAX	120
			MIN	104	MIN	108
Total Solids	MG/L	SM 2540 B	AVG	213	AVG	216
			MAX	214	MAX	230
			MIN	212	MIN	209
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.56	AVG	2.39
			MAX	2.75	MAX	2.39
			MIN	2.30	MIN	2.39
Sulfate	MG/L	SM 4500-SO4 E	AVG	48.6	AVG	43.2
			MAX	48.6	MAX	43.2
			MIN	48.6	MIN	43.2
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.69	AVG	2.64
			MAX	2.82	MAX	2.78
			MIN	2.60	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	371	AVG	372
			MAX	371	MAX	372
			MIN	371	MIN	372
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	39.5	AVG	30.3
			MAX	43.3	MAX	31.8
			MIN	39.1	MIN	27.3
Turbidity	NTU	SM 2130 B	AVG	0.09	AVG	0.06
			MAX	0.61	MAX	0.06
			MIN	0.05	MIN	0.03