

Drinking Water Quality Report
Date Range: 01-MAR-2012 to 31-MAR-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.7
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	59	AVG	62
			MAX	66	MAX	72
			MIN	50	MIN	54
Total Hardness	MG/L	SM 2340 C	AVG	108	AVG	111
			MAX	113	MAX	118
			MIN	103	MIN	106
Total Solids	MG/L	SM 2540 B	AVG	209	AVG	208
			MAX	216	MAX	218
			MIN	198	MIN	194
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.58	AVG	2.45
			MAX	2.80	MAX	2.68
			MIN	2.35	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	49.5	AVG	44.9
			MAX	51.7	MAX	44.9
			MIN	47.3	MIN	44.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.66	AVG	2.54
			MAX	2.82	MAX	2.66
			MIN	2.44	MIN	2.39
Conductivity	UMHOS/cm	SM 2510 B	AVG	376	AVG	380
			MAX	377	MAX	380
			MIN	375	MIN	380
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	47.9	AVG	34.8
			MAX	60.4	MAX	37.8
			MIN	38.8	MIN	29.5
Turbidity	NTU	SM 2130 B	AVG	0.08	AVG	0.03
			MAX	0.10	MAX	0.05
			MIN	0.05	MIN	0.02