

Drinking Water Quality Report
Date Range: 01-MAY-2012 to 31-MAY-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.7
			MAX	9.8	MAX	9.8
			MIN	9.6	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	63	AVG	71
			MAX	68	MAX	77
			MIN	57	MIN	64
Total Hardness	MG/L	SM 2340 C	AVG	99	AVG	106
			MAX	103	MAX	112
			MIN	92	MIN	99
Total Solids	MG/L	SM 2540 B	AVG	203	AVG	206
			MAX	210	MAX	207
			MIN	193	MIN	204
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.61	AVG	2.45
			MAX	2.75	MAX	2.55
			MIN	2.45	MIN	2.35
Sulfate	MG/L	SM 4500-SO4 E	AVG	37.6	AVG	35.9
			MAX	38.9	MAX	35.9
			MIN	35.1	MIN	35.8
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.82	AVG	2.69
			MAX	2.95	MAX	2.80
			MIN	2.72	MIN	2.54
Conductivity	UMHOS/cm	SM 2510 B	AVG	346	AVG	359
			MAX	362	MAX	368
			MIN	335	MIN	349
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	50.2	AVG	31.3
			MAX	57.1	MAX	36.7
			MIN	39.2	MIN	25.7
Turbidity	NTU	SM 2130 B	AVG	0.08	AVG	0.04
			MAX	0.22	MAX	0.06
			MIN	0.05	MIN	0.03