

Drinking Water Quality Report
Date Range: 01-DEC-2013 to 31-DEC-2013

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3
-----	----	-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.5
			MAX	9.7	MAX	9.6
			MIN	9.4	MIN	9.3
Total Alkalinity	MG/L	SM 2320 B	AVG	59	AVG	55
			MAX	65	MAX	60
			MIN	54	MIN	50
Total Hardness	MG/L	SM 2340 C	AVG	112	AVG	109
			MAX	119	MAX	117
			MIN	106	MIN	102
Total Solids	MG/L	SM 2540 B	AVG	205	AVG	203
			MAX	226	MAX	213
			MIN	188	MIN	197
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.70	AVG	2.56
			MAX	2.90	MAX	2.90
			MIN	2.55	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	47.6	AVG	49.4
			MAX	47.8	MAX	49.4
			MIN	47.4	MIN	49.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.98	AVG	2.75
			MAX	3.25	MAX	2.97
			MIN	2.47	MIN	2.61
Conductivity	UMHOS/cm	SM 2510 B	AVG	354	AVG	347
			MAX	354	MAX	347
			MIN	353	MIN	347
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	35.0	AVG	42.6
			MAX	45.6	MAX	49.9
			MIN	28.4	MIN	38.0
Turbidity	NTU	SM 2130 B	AVG	0.09	AVG	0.05
			MAX	0.11	MAX	0.07
			MIN	0.03	MIN	0.03