

Drinking Water Quality Report  
Date Range: 01-JUL-2013 to 31-JUL-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.9	MAX	9.8
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	63	AVG	67
			MAX	70	MAX	72
			MIN	55	MIN	57
Total Hardness	MG/L	SM 2340 C	AVG	97	AVG	102
			MAX	105	MAX	106
			MIN	89	MIN	93
Total Solids	MG/L	SM 2540 B	AVG	187	AVG	193
			MAX	210	MAX	212
			MIN	158	MIN	178
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.74	AVG	2.38
			MAX	2.98	MAX	2.55
			MIN	2.45	MIN	2.00
Sulfate	MG/L	SM 4500-SO4 E	AVG	40.4	AVG	36.4
			MAX	42.0	MAX	36.4
			MIN	38.8	MIN	36.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.75	AVG	2.63
			MAX	2.90	MAX	2.76
			MIN	2.51	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	345	AVG	349
			MAX	346	MAX	349
			MIN	343	MIN	349
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	38.5	AVG	36.0
			MAX	49.4	MAX	41.4
			MIN	29.7	MIN	32.6
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.12	MAX	0.07
			MIN	0.03	MIN	0.02