

Drinking Water Quality Report
Date Range: 01-AUG-2016 to 31-AUG-2016

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.9	MAX	9.8	MAX	9.7
			MIN	9.6	MIN	9.4	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	46	AVG	48	AVG	59
			MAX	54	MAX	56	MAX	64
			MIN	39	MIN	43	MIN	55
Total Hardness	MG/L	SM 2340 C	AVG	72	AVG	75	AVG	81
			MAX	76	MAX	87	MAX	86
			MIN	65	MIN	71	MIN	75
Total Solids	MG/L	SM 2540 B	AVG	127	AVG	135	AVG	161
			MAX	208	MAX	191	MAX	232
			MIN	82	MIN	98	MIN	102
Chloramines	MG/L	SM 4500-CL F	AVG	2.83	AVG	2.71	AVG	2.75
			MAX	3.15	MAX	2.95	MAX	3.10
			MIN	2.35	MIN	2.25	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	20.0	AVG	22.0	AVG	38.0
			MAX	27.5	MAX	21.7	MAX	38.2
			MIN	11.7	MIN	21.7	MIN	38.2
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.91	AVG	2.71	AVG	2.89
			MAX	3.16	MAX	2.94	MAX	3.01
			MIN	2.58	MIN	2.39	MIN	2.78
Conductivity	UMHOS/cm	SM 2510 B	AVG	257	AVG	254	AVG	306
			MAX	259	MAX	254	MAX	306
			MIN	254	MIN	254	MIN	306
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	66.7	AVG	55.7	AVG	46.7
			MAX	91.1	MAX	59.1	MAX	49.5
			MIN	41.6	MIN	52.7	MIN	43.9
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04	AVG	0.05
			MAX	0.11	MAX	0.06	MAX	0.09
			MIN	0.05	MIN	0.02	MIN	0.03