

Drinking Water Quality Report
Date Range: 01-JUL-2016 to 31-JUL-2016

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.7	AVG	9.6
			MAX	9.9	MAX	9.8	MAX	9.7
			MIN	9.6	MIN	9.4	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	50	AVG	51	AVG	61
			MAX	57	MAX	55	MAX	63
			MIN	45	MIN	45	MIN	58
Total Hardness	MG/L	SM 2340 C	AVG	74	AVG	76	AVG	82
			MAX	82	MAX	84	MAX	88
			MIN	70	MIN	71	MIN	75
Total Solids	MG/L	SM 2540 B	AVG	92	AVG	96	AVG	116
			MAX	114	MAX	106	MAX	120
			MIN	74	MIN	86	MIN	108
Chloramines	MG/L	SM 4500-CL F	AVG	2.83	AVG	2.72	AVG	2.78
			MAX	3.25	MAX	3.00	MAX	3.10
			MIN	2.55	MIN	2.20	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.0	AVG	30.0	AVG	37.0
			MAX	35.3	MAX	29.6	MAX	37.3
			MIN	34.5	MIN	29.6	MIN	37.3
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.89	AVG	2.68	AVG	2.84
			MAX	3.09	MAX	2.85	MAX	2.99
			MIN	2.64	MIN	2.49	MIN	2.74
Conductivity	UMHOS/cm	SM 2510 B	AVG	253	AVG	259	AVG	298
			MAX	255	MAX	259	MAX	298
			MIN	251	MIN	259	MIN	298
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	72.2	AVG	57.2	AVG	38.3
			MAX	79.6	MAX	58.8	MAX	39.3
			MIN	66.0	MIN	55.5	MIN	37.3
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03	AVG	0.05
			MAX	0.11	MAX	0.10	MAX	0.09
			MIN	0.03	MIN	0.02	MIN	0.03