

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 01/01/2022 - 01/31/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6	
		Max	9.7	Max	9.7	Max	9.7	
		Min	9.6	Min	9.5	Min	9.4	
Total Alkalinity	mg/L as CaCO3	Avg	68	Avg	64	Avg	74	
		Max	72	Max	72	Max	80	
		Min	64	Min	56	Min	69	
Total Hardness	mg/L as CaCO3	Avg	105	Avg	103	Avg	99	
		Max	108	Max	112	Max	104	
		Min	101	Min	94	Min	93	
Total Solids	mg/L	Avg	213	Avg	222	Avg	206	
		Max	242	Max	234	Max	230	
		Min	176	Min	204	Min	192	
Total Chloramines	mg/L	Avg	2.91	Avg	2.77	Avg	2.87	
		Max	3.00	Max	3.05	Max	3.00	
		Min	2.80	Min	2.58	Min	2.65	
Total Organic Carbon	mg/L	Avg	2.65	Avg	2.40	Avg	2.45	
		Max	2.74	Max	2.47	Max	2.50	
		Min	2.56	Min	2.35	Min	2.40	
Conductivity	umhos/cm	Avg	339	Avg	329	Avg	353	
		Max	339	Max	329	Max	353	
		Min	338	Min	329	Min	353	
Total Trihalomethanes	ug/L	Avg	25.0	Avg	33.5	Avg	27.5	
		Max	25.5	Max	33.5	Max	27.5	
		Min	24.4	Min	33.5	Min	27.5	
Turbidity	NTU	Avg	.07	Avg	.03	Avg	.03	
		Max	.09	Max	.11	Max	.05	
		Min	.05	Min	.02	Min	.04	