

## **Inspection Preparation Checklist**

- o Certificate of Occupancy for Da care (from the City of Austin) must be provided.
- o Address Numbers must be on the building and be clearly visible form the street.
- Lighted Exit Signs with power backup is required when there is more than one exit out of a room or area.
- Emergency Lighting is required in interior stairs, corridors, and windowless areas with student occupancy. (Most classrooms may have flashlights for emergency lighting per TxDPRS.)
- All Exit Doors must open easily without binding or sticking. Exit Door Hardware must work properly.
  All Exit Paths must be free of obstructions.
- Fire Alarm System and Fire Sprinkler System (if applicable) must be inspected and properly tagged within the last 12 months. Kitchen Hood Systems – within the last 6 months.
- Smoke Detectors must be provided in corridors, at stair doors, lounges, recreation areas, and sleeping rooms (per fire code). TxDPRS requires smoke detectors in every area that has children. If a Fire Alarm is present, then ALL smoke detectors must be tied-in to this system.
- Portable Fire Extinguisher, at least a 2A10BC-type, must be positioned every 75 feet of travel distance and one within 30 feet of cooking equipment. It must be inspected and properly tagged within the las 12 months.
- o **Electrical Outlet Covers**. Approved covers need to be on all outlets and light switches-no cracks.
- o **Playgrounds.** Each fenced yard must have at least 2 exits. Employees must be able open the gates/lo ks *immediately* in an emergency.
- o Fire Drills, Evacuation Plans, Swimming Pools, etc.