



Austin Fire Department

Fire Marshal's Office

6310 Wilhelmina Delco Dr., Austin, TX 78752

AFDMobileVending@AustinTexas.gov

Propane System Inspection Report

Piping shall be tested annually at not less than 3 psig for 10 minutes before appliances are Documentation of test, within 90 days of Health/Fire Inspection, must be provided at time of inspection. Receipt from inspection and copy of license from LP Gas Technician that performed the test is required for Fire sign off.

Licensed Individual's Information

Name:

Address:

Phone Number:

Railroad Commission of Texas Category of License and License Number:

Date of Inspection:

Mobile Vending Unit Name:

License Plate and VIN:

| | Pass | Fail |
|--------------------|-----------------------|-----------------------|
| System Plumbing | <input type="radio"/> | <input type="radio"/> |
| Appliances | <input type="radio"/> | <input type="radio"/> |
| Propane Tank | <input type="radio"/> | <input type="radio"/> |
| Pressure/Leak Test | <input type="radio"/> | <input type="radio"/> |

The leak test and inspection of the propane system was performed in accordance with the Texas Railroad Commission the National Fire Protection Standard 58 – Liquefied Petroleum Gas Code

Licensed Individual's Signature: