



Austin Fire Department

Fire Marshal's Office

6310 Wilhelmina Delco Dr., Austin, TX 78752

AFDMobileVending@AustinTexas.gov

Propane System Inspection Report

Piping shall be pressure tested annually at not less than 3 psig for a minimum of 10 minutes without appliances connected and at system pressure with appliances.

This form, filled out by the LP Gas Technician, must be provided at time of inspection.

Receipt from inspection and copy of license from LP Gas Technician that performed the test is required.

Licensed LP Gas Technician's Information

Name:

Business Address:

Phone Number:

Railroad Commission of Texas License Category and License Number:

Mobile Vending Unit Information

Date of Inspection:

Mobile Vending Unit Name:

License Plate or Vehicle Identification Number of Mobile Vending Unit:

	Pass	Fail
System Plumbing	<input type="radio"/>	<input type="radio"/>
Appliances approved for propane	<input type="radio"/>	<input type="radio"/>
Shut offs at each appliance and supply	<input type="radio"/>	<input type="radio"/>
Propane Tank	<input type="radio"/>	<input type="radio"/>
Pressure/Leak Test	<input type="radio"/>	<input type="radio"/>

The leak test and inspection of the propane system was performed in accordance with the Texas Railroad Commission the National Fire Protection Standard 58 – Liquefied Petroleum Gas Code

Licensed LP Gas Technician's Signature: _____