



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for

WATER METER AND WASTEWATER CLEANOUT BOXES AND LIDS

USING DEPARTMENT: Austin Water **PREPARED BY:** David Rinn **ISSUED:** 08/05/85

REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 10/01/23

- DESCRIPTION:** Boxes and lids for water meters, wastewater service cleanouts, and force main cleanouts shall comply with the following:
1. Minimum Tier 8 load rating (per ANSI/SCTE 77) or equivalent.
 2. Manufactured using recycled material with the *RECYCLED* logo and the *AUSTIN WATER* logo molded into the lid.
 3. Boxes shall be a single molded piece.
 4. Lids shall contain a UV inhibitor, a molded keyhole, and a molded tread pattern for skid resistance.
 5. For Potable and Reclaimed Meters (5/8", 3/4", 1", 1 1/2" and 2"):
 - a. Lids shall contain: AMI radio-frequency transparency (as certified by AW approved vendor); A locking mechanism (for 1" or smaller meters) or anti-float material with SG>1 (for 1 1/2" or 2" meters); Universal AMI mounts (with specification of mount configuration under lid).
 - b. Potable Meters: Box and lid shall be black with "WATER METER" molded into the lid.
 - c. Reclaimed Meters: Box shall be black with purple lid that has "RECLAIMED METER" molded into the lid.
 - d. Key shall be locally available.
 6. For Wastewater Service Line Cleanouts: Box and lid shall be green; Lid shall have "SEWER" molded into the lid.
 7. For Force Main Cleanouts: Box and lid shall be black; Lid shall have "SEWER" molded into the lid.

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|--------------|---|--|----------|
| 04/01/10 | DFW PLASTICS, INC. P.O. Box 648 Bedford, TX 76095 | <p>Potable Water Meter Box with AMI Lid</p> <p><u>Sizes 5/8", 3/4" and 1"</u></p> <p>Single:</p> <p>Lid DFW37C-AF1KA_STAR_AW-LID Body DFW37C-14-BODY Combination DFW37C-14-AF1KA_STAR_AW</p> <p>Double:</p> <p>Lid DFW38C-AF1KA_STAR_AW-LID Body DFW38C-14-BODY Combination DFW38C-14-AF1KA_STAR_AW</p> <p><u>Size 1 1/2" (Single meter only)</u></p> <p>Lid DFW65C-AF1KA_STAR_AW-LID Body DFW65C-14-BODY Combination DFW65C-14-AF1KA_STAR_AW</p> <p><u>Size 2" (Single meter only)</u></p> <p>Lid DFW1730F-AF1KA_STAR_AW-LID Body DFW1730F-12-BODY Combination DFW1730F-12-AF1KA_STAR_AW</p> | R. Lamb |



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for

WATER METER AND WASTEWATER CLEANOUT BOXES AND LIDS

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|--------------|---|---|----------|
| 01/01/18 | DFW PLASTICS, INC. P.O. Box 648 Bedford, TX 76095 | <p>Reclaimed Water Meter Box with Purple AMI Lid</p> <p><u>Sizes 5/8", 3/4" and 1"</u> Lid DFW37C-AF5MBA_STAR_AW-LID Body DFW37C-14-BODY Combination DFW37C-14-AF5MBA_STAR_AW</p> <p><u>Sizes 1 1/2" and 2"</u> Lid DFW1730F-AF5MBA_STAR_AW-LID Body DFW1730F-12-BODY Combination DFW1730F-12-AF5MBA_STAR_AW</p> | J. Kyle |
| 01/01/19 | DFW PLASTICS, INC. P.O. Box 648 Bedford, TX 76095 | <p>Box and Lid for Wastewater Service Cleanouts</p> <p>Lid DFW1017-2 SEWER AW-LID Body DFW1017NP2-10-BODY Combination DFW1017NP2-10-2 SEWER AW</p> | J. Kyle |
| 01/01/19 | DFW PLASTICS, INC. P.O. Box 648 Bedford, TX 76095 | <p>Box and Lid for Force Main Cleanout</p> <p>Lid DFWB40C-1 SEWER AW LID Body DFWB40WBCNP-14-BODY Combination DFWB40WBCNP-14-1 SEWER AW</p> | J. Kyle |

NOTES:

1. These products are NOT to be installed in driveways or roadways.

LATEST REVISIONS (since 10/01/22):

1. Updated part numbers for DFW water meter lids.