



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
DUCTILE IRON SERVICE SADDLES (4-inch to 24-inch)

USING DEPARTMENT: Austin Water **PREPARED BY:** Bill Flynn, P.E. **ISSUED:** 01/23/78
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 07/01/24

DESCRIPTION: Service Saddles (for tapping potable and reclaimed water services) shall comply with the following:

1. 12-mil nylon-coated ductile iron saddle
2. Flat stainless steel band (single or double straps) secured with four (4) stainless steel bolts
3. Sizes are 4" x 1" through 24" x 2" for DI or PVC C900 pipe O.D.
4. AWWA C800, where applicable

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/03/94	SMITH-BLAIR, INC. P.O. Box 5337 Texarkana, TX 75505	Series 317 (4" – 12")	W. Flynn
04/03/95	FORD METER BOX COMPANY P.O. Box 443 Wabash, IN 46992-0443	FC202 (4" – 24")	W. Flynn
01/03/94	POWERSEAL PIPELINE PRODUCTS, CO. 1619 Eastside Drive Wichita Falls, TX 76307	Series 3417 (4" – 24")	W. Flynn
01/02/96 07/01/24	MUELLER COMPANY 500 West Eldorado Street Decatur, IL 62525	DR2S Series (4"-16") DR2W Series (24" only)	R. Lamb
01/02/97	JCM INDUSTRIES, INC. P.O. Box 1220 Nash, TX 75569-1220	406 Coated Wide Body (4" – 24") (See Note 2)	W. Flynn

NOTES:

1. Bolt opening on one side or both sides of body must fully enclose strap bolts.
2. Only the following service clamps are allowed for use on HDPE pipe: JCM 406 Coated Wide Body. Service clamps that require spring washer are not allowed for use with HDPE pipe.

LATEST REVISIONS (since 04/01/24):

1. Changed SPL name from "DOUBLE STRAP SERVICE CLAMPS" to "DUCTILE IRON SERVICE SADDLES (4-inch to 24-inch)".
2. Revised DESCRIPTION Nos. 2 and 3.
3. Updated PRODUCT IDENTIFICATION/COMMENT to show approved sizes.
4. Removed MUELLER COMPANY, D2NS Series and added DR2W Series 24" only.
5. Removed manufacturers: ROMAC INDUSTRIES, INC., DRESSER PIPING SPECIALTIES, and A.Y. McDONALD.