



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
JOINT RESTRAINT DEVICES FOR DUCTILE IRON PIPE

USING DEPARTMENT: Austin Water **PREPARED BY:** William Flynn, P.E. **ISSUED:** 03/24/83
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 07/01/23

DESCRIPTION: Externally-mounted devices used to restrain DI pipe bell and spigot (push-on) joints and mechanical joints and to restrain DI pipe spigots to DI fittings and valves. The devices shall be of the wedge-action type or backup-ring, joint harness type meeting the following criteria:

1. The primary components of these devices such as restrainer gland body, wedge, wedge actuator, and backup ring body shall be ductile iron.
2. The devices shall have a working pressure rating of 350 psi for sizes 4" – 16" and 250 psi for larger than 16".
3. Glands and backup rings shall be black.
4. Glands and backup rings shall have an epoxy or polyester thermoset powder coat or epoxy electrocoat (e-coat) finish. A top coat may be applied over the base powder coat or e-coat.
5. Wedges, actuating bolts, and torque control nuts that are part of wedge-action devices shall have a fluoropolymer or e-coat finish. T-head bolts and nuts shall be plain high strength low alloy (HSLA) steel.
6. Threaded thrust rods and nuts and clamping bolts and nuts used with harness type devices shall be HSLA steel having a fluoropolymer finish.
7. All components necessary for installation of harness (bell-to-spigot) type devices shall be provided by the device manufacturer.
8. The only approved products are those having the exact same identification as listed below and only in the sizes indicated.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/96	EBAA IRON, INC. Box 857 Eastland, TX 76448	Megalug: Series 1100 (4" – 48") Part No.11xxDEC Series 1700 (4" – 48") Part No.17xx00Y Megaflange Restrained Flange Adapter: Series 2104 to 2112, 4"-12", Black MJ retainer gland for DI pipe (see Note 4)	R. Lamb J. Kyle
10/01/00	UNI-FLANGE/DIVISION OF FORD METER BOX CO. P.O. Box 443 Wabash, IN 46992-0443	Uni-Flange: Series 1400 (4" – 48") Part No. UFR-1400-xx-I/U Series 1450 (4" – 12") Part No. UFR-1450-xx-RB-I/U	R. Lamb
04/01/98	STAR PIPE PRODUCTS, INC. (SP, CD, XY Foundries, China) 4018 Westhollow Pkwy. Houston, TX 77082	Stargrip Series 3000 Item Code SGDPKSxxN (4" - 8") Item Code SGDPKSxx (12" – 48") Stargrip Series 3100P Item Code SGDPGFSxxNCB (4" - 8", 16", 24") Item Code SGDPGFSxxCB (12", 30", 36") Item Code SGDPGSxxCB (42", 48") Super Flange Restrained Flange Adapter: Series 7200, 4"-12", Black MJ retainer gland for DI pipe (see Note 4)	R. Lamb J. Kyle



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**
for
JOINT RESTRAINT DEVICES FOR DUCTILE IRON PIPE

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
11/26/01	SIGMA CORP (A-1 Foundry, China) 5000 Askins Lane Houston, TX 77346	One-Lok SLDE (4" – 64") Tag w/Part No. SLDE-X## (wedge action type only)	K. Flowers J. Kyle
07/01/09	TYLER UNION / DIVISION OF McWANE 1501 W. 17 th St. Anniston, AL 36201	TUFGrip Series 1000 (4" – 48") Item Code MJ TUFGRipTLD w/TUFBond Coating	R. Lamb
04/01/17	ACCUCAST (EG Foundry, China) 415 South 21 st St. Waco, TX 76706	Acculok ALDI (4" – 12") Item Code ALDIxx	J. Kyle
04/01/17	SIP INDUSTRIES (EF Foundry, China) 2900 Patio Dr. Houston, TX 77017	EZ Grip EZD (4" – 48") Item Code EZDxxE	J. Kyle

NOTES:

1. These devices are not to be used on plain-end DI fittings or on cast iron, PVC, HDPE, or asbestos cement pipe.
2. Warning tape shall be placed on top of the polyethylene wrap around DI pipe restrained with these devices for the full length of restrained joint pipe and fittings. The warning tape shall be yellow and shall have black lettering at least 2 inches high that states "Restrained Joint / Junta de Restriccion" at intervals not exceeding 24 inches. The warning tape shall be polypropylene having a minimum thickness of 2 mils, a minimum width of 3 inches, and adhesive backing on the side opposite the lettering.
3. xx or ## in the Item Code or Part Number refers to the nominal size of the device.
4. Restrained Flange Adapters are only allowed when project plan and/or detail sheets specifically require their use.

[Inspector—show location of restrained pipe and fittings on intersection drawings. Also show on record drawings along with manufacturer's name.]

LATEST REVISIONS (since 01/01/22):

1. Updated address for Sigma Corp.