



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
JOINT RESTRAINT DEVICES FOR PVC PIPE**

USING DEPARTMENT: Austin Water **PREPARED BY:** Jeff A. Kyle, P.E. **ISSUED:** 10/01/19
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 10/01/20

DESCRIPTION: Externally-mounted devices used to restrain PVC bell and spigot (push-on) joints and to restrain PVC pipe spigots to DI fittings and valves. The devices shall be of the wedge-action type or serrated grip-ring, joint harness type meeting the following criteria:

1. The primary components of these devices such as the restrainer gland body, wedge, wedge actuator, and grip-ring body shall be ductile iron.
2. The devices shall have a working pressure rating of 305 psi.
3. These devices are for use only on 4" – 16" diameter pipe.
4. Glands and grip rings shall be red.
5. Glands and grip rings shall have an epoxy or polyester thermoset powder coat or epoxy electrocoat (e-coat) finish. A top coat may be applied over the base powder coat or e-coat.
6. Wedges, actuating bolts, and torque control nuts that are part of wedge-action type devices shall have a fluoropolymer or e-coat finish. T-head bolts and nuts shall be plain high strength low alloy (HSLA) steel.
7. Threaded thrust rods and nuts and clamping bolts and nuts used with harness type devices shall be HSLA steel having a fluoropolymer finish.
8. All components necessary for installation of harness (bell-to-spigot) type devices shall be provided by the device manufacturer.
9. The only approved products are those having the exact same identification as listed below and only in the sizes indicated.

LISTING DATE (See Note 1)	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/96	EBAA IRON, INC. Box 857 Eastland, TX 76448	Megalug Series 2000PV (4" – 12") Part No. 20xxPEC i.e. 20xxPEC Series 1900 (4" – 12") Part No. 19xx00Y	R. Lamb J. Kyle
10/01/00	UNI-FLANGE/DIVISION OF FORD METER BOX CO. P.O. Box 443 Wabash, IN 46992-0443	Uni-Flange: Series 1300 (4" – 12") Part No. UFR-1300-C-xx-RB-RED-I/U Series 1390 (4" – 12") Part No. UFR-1390-C-xx-RB-RED-I/U Series 1500 (4" – 16") Part No. UFR-1500-C-xx-I/U	R. Lamb
04/01/98	STAR PIPE PRODUCTS, INC. (SP, CD, XY Foundries, China) 4018 Westhollow Pkwy. Houston, TX 77082	Stargrip Series 4000G2 (4" – 12") Item Code PVCPKSCB40xxG2	R. Lamb J. Kyle
11/26/01	SIGMA CORP (A-1 Foundry, China) P.O. Box 300 Rt. 537 Goldman Road Cream Ridge, NJ 08514	One-Lok SLCE (4" – 16") Tag w/Part No. SLCE-X##	K. Flowers J. Kyle
07/01/09	TYLER UNION / DIVISION OF McWANE 1501 W. 17 th St. Anniston, AL 36201	TUFGrip Series 2000 (4" – 16") Item Code MJ TUFGripTLP w/TUFBond Coating	R. Lamb



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
JOINT RESTRAINT DEVICES FOR PVC PIPE**

04/01/17	ACCUCAST (EG Foundry, China) 415 South 21 st St. Waco, TX 76706	Acculok ALPV (4" – 12") Item Code ALPVxx	J. Kyle
04/01/17	SIP INDUSTRIES (EF Foundry, China) 2900 Patio Dr. Houston, TX 77017	EZ Grip EZP (4" – 16") Part No. EZPVCxxE: EZ Grip PTP Series (4" – 16") Part No. PTPVCxxEB	J. Kyle

NOTES:

1. If the listing date precedes the issue date of this SPL, the manufacturer had PVC joint restraint products originally included on SPL WW-27A.
2. Specifying or use of restraint devices outside the indicated size range requires prior approval by Austin Water on a project-by-project basis.
3. Warning tape shall be placed on the top of PVC pipe restrained by these devices. The warning tape shall be yellow and shall have black lettering at least 2 inches high that states "Restrained Joint / Junta de Restriccion" at intervals not exceeding 24 inches. The warning tape shall be polypropylene having a minimum thickness of 2 mils, a minimum width of 3 inches, and adhesive backing on the side opposite the lettering.
4. xx or ## in the Item Code or Part Number refers to the nominal size of the device.

[Inspector—show location of restrained pipe and fittings on intersection drawings. Also show on record drawings along with manufacturer's name.]

LATEST REVISIONS (since 01/01/20):

1. Corrected Ebaa Series 2000 Part Number.