



**CITY OF AUSTIN**  
**TEMPORARY STANDARD PRODUCTS LIST**  
for  
**PVC WATER PIPE (4-INCH TO 16-INCH DIAMETER)**  
**EXPIRES ON JUNE 30, 2023**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** Jeff A. Kyle, P.E.      **ISSUED:** 07/01/22  
**EXPIRES:** 06/30/23

**DESCRIPTION:** Pipe, polyvinyl chloride (PVC), 4" through 16" cast iron pipe size O.D. with Rieber-type, steel-reinforced elastomeric gasket joints for water service and meeting AWWA C900 pressure class 235 (DR18).

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/22	JM EAGLE (formerly J M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039	4" through 16" See notes below	J. Kyle
07/01/22	WESTLAKE PIPE & FITTINGS (Formerly NAPCO / North American Pipe Co.) 2801 Post Oak Boulevard, Suite 410 Houston, TX 77056	4" through 16" See notes below	J. Kyle
07/01/22	DIAMOND PLASTICS CORPORATION P.O. Box 2748 Lubbock, TX 79408-2748	4" through 16" See notes below	J. Kyle
07/01/22	VINYLECH CORPORATION 201 South 61 <sup>st</sup> Avenue Phoenix, AZ 85043	4" through 12" See notes below	J. Kyle
07/01/22	NORTHERN PIPE PRODUCTS 1309 39 <sup>th</sup> Street NW Fargo, ND 58102	4" through 12" See notes below	J. Kyle
07/01/22	JET STREAM (formerly Pipelife Jet Stream Inc.) 1700 South Lincoln Street Siloam Springs, AR 72761	4" through 12" See notes below	J. Kyle
07/01/22	SANDERSON PIPE CORPORATION 1 Enterprise Blvd Sanderson, FL 32087	4" through 12" See notes below	J. Kyle

**NOTES:**

- Material must comply with requirement of description above and be rated above design pressure. Acceptable sizes are 4", 6", 8", 12" and 16".
- Pipe with a whitened exterior (fading of color) that was manufactured more than two (2) years before the proposed installation date shall be rejected.
- AWWA C900 water pipe shall not be used in easements on private property and shall not be used for wastewater force mains or to convey anything but potable water.
- Changes in direction of PVC pipe shall only be by use of fittings or by deflecting straight pipe sections at joints.
- Longitudinal bending of pipe is not allowed.
- Deflection of pipe at fittings is not allowed.
- Deflection of straight pipe sections shall not exceed 1 degree at each joint (even if joint restraint devices are installed), which corresponds to the following offset in pipe alignment:

Length of Pipe, ft  
20

Offset, inches  
4 maximum

Allowable Radius of Curvature, ft  
1,146 minimum



**CITY OF AUSTIN**  
**TEMPORARY STANDARD PRODUCTS LIST**  
for  
**PVC WATER PIPE (4-INCH TO 16-INCH DIAMETER)**  
**EXPIRES ON JUNE 30, 2023**

**LATEST REVISIONS (since 07/01/22):**

1. This temporary SPL allows DR18 PVC. DR14 will be required after June 30, 2023, unless otherwise approved.
2. Updated NAPCO / North American Pipe Co. to Westlake Pipe & Fittings.
3. Updated Pipelife Jet Stream Inc. to Jet Stream, and updated company mailing address.