



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
AIR RELEASE/VACUUM RELIEF VALVES FOR POTABLE WATER

USING DEPARTMENT: Austin Water **PREPARED BY:** Robert Lamb, P.E. **ISSUED:** 10/01/03
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 01/01/23

DESCRIPTION: Automatic combination air and vacuum relief valves (CARVs) for potable water service meeting the following requirements:

1. Compliance with AWWA C512
2. Minimum pressure rating 200 psi
3. Standard sizes shall be 2" through 6" only, with matched inlet and outlet sizes
4. ANSI / NSF 61 Certified for potable use

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/03	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-040 D-060	R. Lamb
04/01/04	BERMAD 9424 West Little York Rd Houston, TX 77040	Model C75	R. Lamb
07/01/10	DEZURIK/APCO (formerly APCO VALVE & PRIMER CORP.) 250 Riverside Ave N Sartell, MN 56377	Series 1800	R. Lamb
07/01/18	H-TEC 1061 Triad Court, West Oak Business Park II, Ste. 5 Marietta, GA 30062	Models 992 & 993	J. Kyle
01/01/23	RF VALVES 1342 Charwood Road, Suite A Hanover, MD 21076	Vent-O-Mat RBX Series	J. Kyle

NOTES:

1. Size and optional features to be shown on approved engineering drawings.

LATEST REVISIONS (Since 07/01/18):

1. Updated DESCRIPTION and NOTES.
2. Added RF VALVES, Vent-O-Mat RBX Series.