



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**

for  
**COMBINATION AIR VALVES FOR POTABLE AND RECLAIMED WATER**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** Robert Lamb, P.E.      **ISSUED:** 10/01/03  
**REVISED BY:** Jeff A. Kyle, P.E.      **REVISED:** 01/01/24

**DESCRIPTION:** Combination air valves (CAVs) for potable and reclaimed water service meeting the following requirements:

1. Compliance with AWWA C512
2. Minimum pressure rating 200 psi
3. Standard sizes shall be 2", 4" or 6" only, with matched inlet and outlet sizes
4. NSF/ANSI 61 Certified for potable use

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/03	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-040 D-060	R. Lamb
04/01/04	BERMAD 9424 West Little York Rd Houston, TX 77040	Model C75	R. Lamb
07/01/10	DEZURIK/APCO (formerly APCO VALVE & PRIMER CORP.) 250 Riverside Ave N Sartell, MN 56377	Series 1800	R. Lamb
07/01/18	H-TEC 1061 Triad Court, West Oak Business Park II, Ste. 5 Marietta, GA 30062	Models 992 & 993	J. Kyle
01/01/23	RF VALVES 1342 Charwood Road, Suite A Hanover, MD 21076	Vent-O-Mat RBX Series	J. Kyle

**NOTES:**

1. Size and optional features to be shown on approved engineering drawings.
2. Paint body purple (Pantone 522) for reclaimed water.

**LATEST REVISIONS (Since 07/01/23):**

1. Updated SPL NAME and DESCRIPTION to include Reclaimed Service.
2. Updated DESCRIPTION No. 3 to allow only 2", 4" and 6" CAVs.
3. Added Note 2.