



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
COMBINATION AIR VALVES FOR POTABLE AND RECLAIMED WATER

USING DEPARTMENT: Austin Water **PREPARED BY:** Robert Lamb, P.E. **ISSUED:** 10/01/03
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 04/01/24

DESCRIPTION: Combination air valves (CAVs) for potable and reclaimed water service meeting the following requirements:

1. Compliance with AWWA C512
2. Minimum pressure rating 200 psi
3. Standard sizes shall be 2", 4" or 6" only, with matched inlet and outlet sizes
4. NSF/ANSI 61 Certified for potable use

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/03	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-040 (2") D-060 (4", 6")	R. Lamb
04/01/04	BERMAD 9424 West Little York Rd Houston, TX 77040	Model C70	R. Lamb
07/01/10	DEZURIK/APCO (formerly APCO VALVE & PRIMER CORP.) 250 Riverside Ave N Sartell, MN 56377	145C (2") 149C (4") 150C (6")	R. Lamb
07/01/18	H-TEC 1061 Triad Court, West Oak Business Park II, Ste. 5 Marietta, GA 30062	Models 992 & 993	J. Kyle
01/01/23	RF VALVES 1342 Charwood Road, Suite A Hanover, MD 21076	Vent-O-Mat RBX Series	J. Kyle

NOTES:

1. Size and optional features to be shown on approved engineering drawings.
2. Paint body purple (Pantone 522) for reclaimed water.

LATEST REVISIONS (Since 01/01/24):

1. Added size information to PRODUCT IDENTIFICATION/COMMENT for A.R.I. FLOW CONTROL.
2. Corrected PRODUCT IDENTIFICATION/COMMENT for BERMAD from 'Model C75' to Model C70'.
3. Corrected PRODUCT IDENTIFICATION/COMMENT for DEZURIK/APCO from 'Series 1800' to '145C (2"), 149C (4"), 150C (6")'.