



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**

for  
**AIR RELEASE/VACUUM RELIEF VALVES FOR RECLAIMED WATER**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** Robert Lamb, P.E.      **ISSUED:** 04/01/10  
**REVISED BY:** Jeff A. Kyle, P.E.      **REVISED:** 01/01/23

**DESCRIPTION:** Air release (combination, automatic)/vacuum relief valve for reclaimed water service only, meeting the following requirements:

1. Compliance with AWWA C512
2. Minimum pressure rating 200 psi
3. Standard sizes shall be 2" through 6" only, with matched inlet and outlet sizes
4. Purple (Pantone 522) Body

<b>LISTING DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>	<b>APPROVAL</b>
04/01/10	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-040	R. Lamb

**NOTES:**

1. Any use of air vacuum valves in combination with air release valves will require that venting or vent piping be acceptably installed and protected.
2. Size and optional features to be shown on approved engineering drawings.

**LATEST REVISIONS (Since 10/01/15):**

1. Updated to new SPL format.
2. Updated DESCRIPTION and NOTES.