



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
COMBINATION AIR VALVES FOR RECLAIMED WATER

USING DEPARTMENT: Austin Water **PREPARED BY:** Robert Lamb, P.E. **ISSUED:** 04/01/10
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 07/01/23

DESCRIPTION: Combination air valves (CAVs) for reclaimed water service only, meeting the following requirements:

1. Compliance with AWWA C512
2. Minimum pressure rating 200 psi
3. Standard sizes shall be 2" through 6" only, with matched inlet and outlet sizes
4. Purple (Pantone 522) Body

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/10	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-040	R. Lamb

NOTES:

1. Size and optional features to be shown on approved engineering drawings.

LATEST REVISIONS (Since 01/01/23):

1. Updated SPL NAME and DESCRIPTION.
2. Removed Note 1