



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
TRANSITION COUPLINGS**

**USING DEPARTMENT:** Austin Water

**PREPARED BY:** Bill Flynn, P.E.

**ISSUED:** 04/07/92

**REVISED BY:** Jeff A. Kyle, P.E.

**REVISED:** 01/01/25

**DESCRIPTION:** Couplings, Transition, Bolted, Welded Steel or Ductile Iron for connecting pipes of same nominal size but having different outside diameters, meeting AWWA C219 and coated inside and outside with fusion bonded epoxy according to AWWA C213. Bolts and nuts shall be high-strength low-alloy (HSLA) steel with a blue fluoropolymer finish.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/07/92	SMITH-BLAIR, INC. P.O. Box 5337 Texarkana, TX 75505	Style 441	K. Flowers
04/07/92	ROMAC INDUSTRIES, INC. 1064 Fourth Avenue South Seattle, WA 98134	Style 501 Style XR 501 4" 4.5-5.6" Stl., DI, CI & AC 6" 6.60-7.60" Stl., DI, CI & AC 8" 8.6-9.75" Stl., DI, CI & AC 10" 11.00-12.15" Stl., DI & AC 12" 13.10-14.40" Stl., DI, CI & AC	K. Flowers
04/07/92	JCM INDUSTRIES, INC. P.O. Box 580 Nash, TX 75569-0580	Style 212	R. Lamb
04/07/92	POWER SEAL CORP. P.O. Box 2014 Wichita Falls, TX 76307	Model 3501 Model 3506	R. Lamb
04/03/95	FORD METER BOX CO. P.O. Box 443 Wabash, IN 46992-0443	Style FC2A	K. Flowers
10/01/03	DRESSER PIPING SPECIALTIES 41 Fisher Avenue Bradford, PA 16701	Style 253 Modular Cast Couplings (4" - 16") Style 253 Modular Long Sleeve Cast Coupling (4" - 16")	J. Kyle

**NOTES:**

**LATEST REVISIONS (since 07/01/11):**

1. Updated to new SPL format.
2. Revised DESCRIPTION to require a blue fluoropolymer finish on all HSLA hardware.