



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**

for  
**POLYETHYLENE TUBING FOR LOW PRESSURE SEWERS**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** Robert Lamb, P.E.      **ISSUED:** 04/01/11  
**REVISED BY:** Jeff A. Kyle, P.E.      **REVISED:** 10/01/20

**DESCRIPTION:** Tubing, polyethylene, meeting ASTM D 2737, CTS-OD, 2" only, made of PE 4710, minimum Pressure Class 250 psi (SDR-9), solid green exterior and clear interior or solid green wall, contrasting-color heat-indented print line. Only compression fittings recommended by the manufacturer may be used and only with stainless steel insert stiffeners.

<b>LISTING DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>	<b>APPROVAL</b>
01/01/11	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockway, NJ 07866	EndoPure	R. Lamb

**NOTES:**

1. Print line shall include all markings required by ASTM D 2737 (nominal tubing size, PE material designation code, pressure rating, ASTM designation D 2737, manufacturer's name or trademark and code, tubing test category). In addition, the print line shall include the date of manufacture that is recognizable as a date, and manufacturer's production code that includes resin source, manufacturing location, and extrusion line.
2. Tracer Tape meeting SPL WW-597 to be installed 12" above top of tubing.

**LATEST REVISIONS (since 04/01/12):**

1. Removed reference to 1" tubing.
2. Updated SPL Format.