



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
BRASS GOODS**

**USING DEPARTMENT:** Austin Water

**PREPARED BY:** David Rinn

**ISSUED:** 02/16/82

**REVISED BY:** Jeff A. Kyle, P.E.

**REVISED:** 07/01/22

**DESCRIPTION:** Brass goods – including but not limited to: corporation stops, ball valves, angle meter stops, and fittings. Service tubing connections shall be made with approved grip ring type compression connections. Pressure rating of at least 200 psi. Shall conform to AWWA C800, where applicable. All brass goods shall contain “NL” casted in the main body or by other methods acceptable to Austin Water.

| LISTING DATE | MANUFACTURER                                                                              | PRODUCT IDENTIFICATION/COMMENT                                                                                                                                                                                                                                                     | APPROVAL              |
|--------------|-------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|
| 04/01/98     | JAMES JONES COMPANY<br>4127 Temple City Blvd.<br>El Monte, CA 91731                       | 2" Corporation Stop: E1935G<br>2" Ball Valve: E1921G<br>2" MIP x 1" Copper Flare Wye: E1583-17<br>2" MIP x 1" Copper Flare Fitting: E1531-17<br>1" Swivel Nut x 1" Compression 90° Bend: E2626G<br>1" Angle Meter Stop (full port): E1963WG                                        | R.Lamb<br>J. Kyle     |
| 04/01/98     | MUELLER COMPANY<br>500 West Eldorado<br>Decatur, IL 62525                                 | 2" Corporation Stop: G2502836N<br>2" Ball Valve: G25172N<br>2" MIP x 1" Copper Flare Wye: H15341-07N<br>2" MIP x 1" Copper Flare Fitting: H15425-07N<br>1" Swivel Nut x 1" Compression 90° Bend: G15076N<br>1" Angle Meter Stop (full port): G24258N                               | K. Flowers<br>J. Kyle |
| 04/01/98     | FORD METER BOX<br>COMPANY<br>P.O. Box 443<br>Wabash, IN 46992-0443                        | 2" Corporation Stop: FB1100-7-G-NL<br>2" Ball Valve: B41-777-G-NL<br>2" MIP x 1" Copper Flare Wye: Y28-247-LN-NL<br>2" MIP x 1" Copper Flare Fitting: C28-47-LN-NL<br>1" Swivel Nut x 1" Compression 90° Bend:<br>L04-44SI-G-NL<br>1" Angle Meter Stop (full port): BA43-444W-G-NL | K. Flowers<br>J. Kyle |
| 10/01/98     | CAMBRIDGE BRASS<br>(Formerly Hays Brass)<br>140 Orion Place<br>Cambridge, Ontario N1R 5V1 | 2" Corporation Stop: 301NL-M7GJ7<br>2" Ball Valve: 202NL-GJ7F7<br>1" Angle Meter Stop (full port): 210NL-GJ4T4                                                                                                                                                                     | R. Lamb<br>J. Kyle    |
| 04/01/98     | A.Y. McDONALD COMPANY<br>Box 508<br>Dubuque, Iowa 52001                                   | 2" Corporation Stop: 74704BGFT<br>2" Ball Valve: 76102WG<br>2" MIP x 1" Copper Flare Wye: 708YSML<br>2" MIP x 1" Copper Flare Fitting: 74753L<br>1" Swivel Nut x 1" Compression 90° Bend: 74776SG<br>1" Angle Meter Stop (full port): 74602BG                                      | R. Lamb<br>J. Kyle    |

**NOTES:**

- When brass goods are used with polyethylene tubing, tubular stainless steel insert stiffeners shall be used. Insert stiffeners shall be by the same manufacturer as the brass goods used.

**LATEST REVISIONS (since 10/01/20):**

- Updated Part No. for A.Y. McDonald Co. 2" MIP x 1" Copper Flare Wye from 708Y2ML to 708YSML.