



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**

for

**POLYETHYLENE BUTT FUSION FITTINGS, MOLDED (4-INCH TO 16-INCH DIAMETER)**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** Jeff A. Kyle, P.E.      **ISSUED:** 01/01/22

**REVISED BY:** Jeff A. Kyle, P.E.      **REVISED:** 07/01/23

**DESCRIPTION:** Butt fusion fittings, molded, polyethylene (PE) for wastewater force mains only, 4 inch to 16 inch nominal diameter meeting the following requirements:

1. Compliance with AWWA C906
2. Compliance with ASTM D3261
3. Materials Designation Code of PE4710 (Cell Class: 445574C)
4. Ductile Iron Pipe Size (DIPS) OD nominal diameters
5. Minimum Pressure Rating of 200 psi
6. All metal glands used for MJ Adapters shall comply with and be labeled as AWWA C110 and shall have an epoxy or polyester thermoset powder coat or epoxy electrocoat (e-coat) finish. A top-coat may be applied over the base powder coat or e-coat.
7. Bolts and nuts used for MJ Adapters shall be high-strength low-alloy steel.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/01/22	GEORG FISCHER CENTRAL PLASTICS 39605 W. Independence Avenue Shawnee, OK 74804	Tees 45° Bends Reducers MJ Adapter & Accessory Kits	J. Kyle
01/01/22	INTEGRITY FUSION PRODUCTS, INC. 270 Parkade Court Peachtree City, GA 30269	Tees 45° Bends Reducers MJ Adapter & Accessory Kits	J. Kyle
01/01/22	STRONGBRIDGE INTERNATIONAL, LLC P.O. Box 58177 Jacksonville, FL 32241	Tees 45° Bends Reducers End Caps	J. Kyle

**NOTES:**

1. Fitting material must comply with requirements of the description above and be rated above design pressure.
2. Sizes for wastewater force mains shall be determined based on specific project requirements.
3. These fittings shall only be used with polyethylene pipe listed on SPL WW-706 and are not to be used for gravity flow wastewater systems.
4. Each fusion technician must be pre-qualified and possess a current certification issued by an independent, industry-recognized certification organization to make butt fusion joints.

**LATEST REVISIONS (Since 01/01/22):**

1. Removed Thrust Restraints (Wall Anchor).
2. Added Description Notes 6 and 7.