



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
JOINT RESTRAINT DEVICES**

USING DEPARTMENT: Austin Water

PREPARED BY: William Flynn, P.E.

ISSUED: 03/24/83

REVISED BY: Jeff A. Kyle, P.E.

REVISED: 04/01/19

DESCRIPTION: Restraint Devices for joints on pipe, fittings, and valves. Devices shall be 1) wedge-action lug-type mechanical joint (MJ) Retainer Glands, 2) split, full-circle grip-ring type with High Strength Low Alloy (HSLA) threaded thrust rods and nuts and stainless steel clamping bolts and nuts, or 3) single-piece, solid-body bolt-through type. For use only with 4" – 48" Ductile Iron (DI) pipe or 4" – 16" AWWA C900 (PVC) pipe as indicated and color-coded as noted. Restraint devices shall have a working pressure rating that equals or exceeds the pressure of the pipe, fittings, or valves on which they are used. The only approved products are those having the exact same identification as listed below and only in the sizes indicated.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/96	EBAA IRON, INC. Box 857 Eastland, TX 76448	Megalug: 1104 to 1148, Black MJ retainer gland for DI pipe 1704 to 1716, Black Bell Joint Restraint Harness for DI pipe w/push-on joints 2004PV to 2012PV, Red MJ retainer gland for PVC pipe Megaflange: 2104 to 2112, Red MJ retainer gland for PVC pipe, not for buried installation PVC Bell Restraint Harness 1500, Red split full-circle grip rings w/HSLA threaded rods and stainless steel clamping bolts	R. Lamb
10/01/00	UNI-FLANGE/DIVISION OF FORD METER BOX CO. P.O. Box 443 Wabash, IN 46992-0443	Uni-Flange: UFR 1300 C-4 to C-16, MJ retainer gland adaptor, Split full-circle grip-rings w/HSLA bolts and stainless steel clamping bolts. Black for DI, red for PVC. UFR 1390 C-4 to C-16, bell restraint harness, Split full-circle grip-rings w/HSLA threaded rods and stainless steel clamping bolts. Black for DI, red for PVC. UFR 1400 D-4 to D-48, Black MJ retainer gland for DI pipe UFR 1450 D-4 to D-16, Black MJ retainer gland for DI pipe with push-on joints UFR 1500 CA-4 to CA-12, Red MJ retainer gland for PVC pipe	R. Lamb



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
JOINT RESTRAINT DEVICES**

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/98	JL, RR, CD, EF, DMY, QB, HX, YS FOUNDRIES (CHINA) STAR PIPE PRODUCTS, INC. 4018 Westhollow Pkwy. Houston, TX 77082	Stargrip: 3000, Black MJ retainer gland for DI pipe, 4" - 48" 4000G2, Red MJ retainer gland for PVC pipe, 4" - 12" PVCgrip: 3500, Red MJ retainer gland for PVC pipe, 4" - 12" PVC Pipe Restrainers 1000, Red split full-circle grip-rings w/HSLA threaded rods and stainless steel clamping bolts for PVC pipe, 4" - 12" 1100, Red split full-circle grip-rings w/HSLA threaded rods and stainless steel clamping bolts for PVC pipe, 4" - 12" Bolt-through Type: Series 100 MJ x MJ Adaptor Super Flange Series 7200, 4" - 12" Red MJ retainer gland for PVC pipe, Black for DI pipe, not for buried installations	R. Lamb J. Kyle
10/01/98	ROMAC INDUSTRIES, INC. P.O. Box 3212 Seattle, WA 98114	GripRing, Yellow MJ retainer gland w/black split full-circle grip-rings for DI or PVC pipe, 4" - 12" RomaGrip, Black MJ retainer gland for DI pipe, 4" - 48" RomaGrip, Red MJ retainer gland for PVC pipe, 4" - 12"	W. Flynn
11/26/01	SIGMA CORP P.O. Box 300 Rt. 537 Goldman Road Cream Ridge, NJ 08514	One Lok: Wedge-Action Type; A-1 Foundry, China (SLD) Black MJ retainer gland for DI pipe, 4" - 48" (SLC) Red MJ retainer gland for PVC pipe, 4" - 12" Bolt-Through Type; BH Foundry MJ Connector, 4" - 12"	K. Flowers J. Kyle
07/01/09	TYLER UNION/DIVISION OF McWANE P.O. Box 309 Anniston, AL 36202	TUFGrip (TLD) Black MJ retainer gland for DI pipe, 4" - 48" (TLP) Red MJ retainer gland for PVC pipe, 4" - 12"	R. Lamb
07/01/11	SMITH-BLAIR, INC. 30 Globe Ave. Texarkana, AR 71854	Bell-Lock Serrated Joint Restraint Harness Model 165 Split full-circle grip-rings w/HSLA threaded rods and stainless steel clamping bolts. Black for DI, 4" - 8" and red for PVC, 4" - 12".	R. Lamb
10/01/12	INFACCT CORP. 7555 Caney Fork Rd. Fairview, TX 37062	Bolt-through Type: Foster MJ x MJ Adaptor	R. Lamb
04/01/17	ACCUCAST 415 South 21 st St. Waco, TX 76706	Acculok: Wedge-Action Type; EG Foundry, China ALDI, 4" - 12", Black MJ retainer gland for DI pipe ALPV, 4" - 12", Red MJ retainer gland for PVC pipe Accu Adaptor: MJxMJ Bolt-through Type	J. Kyle



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
JOINT RESTRAINT DEVICES**

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/17	SIP INDUSTRIES 2900 Patio Dr. Houston, TX 77017	EZ Grip: Wedge-Action Type; EF Foundry, China EZDP, 4" - 48", Black MJ retainer gland for DI pipe EZPVCP, 4" - 16", Red MJ retainer gland for PVC pipe EZ Grip: Split, Full-Circle Grip-Ring Type; EF Foundry, China PTPVC, 4" - 16", Red bell-joint restraint harness for PVC pipe	J. Kyle

NOTES:

1. Only manufacturer's products indicated shall be used.
2. Restraint devices for DI pipe shall have a black coating.
3. Restraint devices for PVC pipe shall have a red coating.
4. These devices are not to be used on Plain-end DI fittings.
5. Specifying or use of restraint devices outside the indicated size range requires prior approval by Austin Water on a project-by-project basis.
6. Threaded thrust rods and nuts used with split, full-circle grip-ring restraint devices must be High Strength Low Alloy steel supplied by the restraint device manufacturer. Galvanized All-thread or similar rod is not allowed.
7. High Strength Low Alloy components must meet AWWA C111.
8. Warning tape shall be placed on the top of PVC pipe restrained by these devices and on the top of polyethylene wrap around DI pipe restrained with these devices for the full length of restrained joint pipe and fittings. The warning tape shall be yellow and shall have black lettering at least 2 inches high that states "Restrained Joint / Junta de Restriccion" at intervals not exceeding 24 inches. The warning tape shall be polypropylene having a minimum thickness of 2 mils, a minimum width of 3 inches, and adhesive backing on the side opposite the lettering.
9. Wedge-action lug-type mechanical joint restraints shall not be attached to cast iron or asbestos concrete pipe without Austin Water approval.

[Inspector—show location of restrained pipe and fittings on intersection drawings. Also show on record drawings along with manufacturer's name.]

LATEST REVISIONS:

1. Deleted size range from Title.
2. Revised size range for devices used on DI in Description.
3. Added size declaration in last sentence of Description.
4. Increased allowable size to 48" for select Megalug, Uni-Flange, Stargrip, RomaGrip, One Lok, TUF Grip, and EZ Grip devices.