



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
SWING CHECK VALVES, AWWA C508**

USING DEPARTMENT: Water Utility **ISSUED:** 08/06/74 **REVIEWED:** 10/01/12 **REVISED:** 10/01/12

PREPARED BY: Jim Edwards **CITY STOCK NUMBER:**

DESCRIPTION: Valves, swing check with outside lever and weight complying with current AWWA C508. Iron Body, bronze mounted for water works service. Copper alloy parts (bronze and brass) shall not contain over 16 percent zinc. Copper alloy UNS No. shall be shown on permanent external marking in addition to markings required by AWWA C508. Effective January 1, 2013, valves purchased for City forces shall be “lead free” and marked by stamping, etching, or casting “NL” in the main body or by other methods acceptable to City. Effective January 4, 2014, all valves must be “lead free.”

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
12/31/85	M & H VALVE COMPANY P.O. Box 2088 Anniston, AL 36202	M & H Style 159-02	J. Edwards
08/06/74	MUELLER COMPANY 500 W. Eldorado St. Decatur, IL 67525	A-2600-6-01	J. Edwards
02/24/87	AMERICAN R/D P.O. Box 3077 Vernon, CT 06066	50 – SC	J. Edwards
01/02/90	APCO VALVE & PRIMER CORP. 1230 So. Wright Blvd. Schaumburg, IL 60193	APCO Series 6000 CLW	J. Edwards
07/01/94	CLOW CORPORATION/VALVE DIVISION P.O. Box 350 Oskaloosa, IA 52577	F – 5382, Style 106LW F – 5345, Style 159 – 02	J. Edwards

NOTE: