



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
STEEL FULL-BODY MJ TAPPING SLEEVES (16" & larger)**

**USING DEPARTMENT:** Water Utility      **ISSUED:** 01/01/09      **REVIEWED:** 07/01/12      **REVISED:** 07/01/12

**PREPARED BY:** Robert Lamb, P.E.      **CITY STOCK NUMBER:**

**DESCRIPTION:** Sleeves, Tapping, 16 inch and larger, meeting AWWA C223, fabricated from carbon steel meeting ASTM A 283 Grade C or ASTM A 36, for use on Cast Iron, Ductile Iron, PVC, and AC pipe. Sleeves shall have split body that completely surrounds pipe. Sleeves shall have mechanical joint body and flanged outlet and shall include plain MJ gaskets, split MJ glands, and side flange gaskets.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/01/09	JCM INDUSTRIES, INC. P.O. Box 1220 Nash, TX 75569	JCM 414 ESS (w/304 stainless steel nuts, bolts, and washers, AWWA C207 Class E 275 psi flange, minimum 200 psi rated body, minimum 12 mil thick epoxy coating inside and out)	R. Lamb
07/01/11	SMITH-BLAIR 30 Globe Ave. Texarkana, AR 71854	Type 623 and 624 (w/304 stainless steel nuts, bolts, and washers, AWWA C207 Class E 275 psi flange, minimum 200 psi rated body, minimum 12 mil thick epoxy coating inside and out)	R. Lamb

- NOTE:**
- To be used only if indicated on AWU-approved drawings.
  - CONTRACTOR'S / SUPPLIER'S **PROJECT** SUBMITTAL MUST INCLUDE MANUFACTURER'S CUT SHEET AND ORDER DATA SHEET THAT LISTS, AMONG OTHER INFORMATION, THE TYPE OF STEEL; TYPE OF NUTS, BOLTS AND WASHERS; TYPE OF COATING; CLASS OF FLANGE; AND PRESSURE RATING OF BODY, ALL MEETING THE REQUIREMENTS IN THE DESCRIPTION ABOVE.
  - CONTRACTOR'S / SUPPLIER'S **PROJECT** SUBMITTAL MUST BE APPROVED BY AWU.