



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**
for
BALL VALVES FOR PROPERTY OWNER'S CUT OFF

USING DEPARTMENT: Water Utility

ISSUED: 07/01/02

REVISED: 07/01/05

PREPARED BY: David Rinn

CITY STOCK NUMBER:

DESCRIPTION: Valves, Ball, with stainless steel handles, used on meter nipple for property owner's cut off. Conforms to specification MSS-SP-110. Threaded ends comply with ANSI B2.1CSA/AGA/CGA certified. All valves shall be full port with chrome-plated bronze ball.

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|---------------------|--|---|-----------------|
| 07/01/02 | MIDLAND METAL MFG 2021 Forest Ave. Kansas City, MO 64108 | IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle and nut ¾" – 948-154ST 1" – 948-155ST | K. Flowers |
| 07/01/02 | NIBCO P.O. Box 1167 Elkhart, IN 46515-1167 | IPS ball valves, full port, SWP 600 CWP with stainless steel lever handle and nut (use only in rectangular or square valve box providing clearance for handle) ¾" – T-585-70-SSHN 1" – T-585-70-SSHN 1½" – T-585-70-SSHN 2" – T-585-70-SSHN | R. Lamb |
| 07/01/04 | MATCO-NORCA P.O. Box 27 Route 22 Brewster, NY 10509 | IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle, nut and washer ¾" – 759T04TS 1" – 759T05TS | R. Lamb |
| 07/01/04 | WEBSTONE CO., INC. P.O. Box 59 Worcester, MA 01613 | IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle, nut and washer ¾" – 41703SSW 1" – 41704SSW 1½" – 41706SSW 2" – 41707SSW | R. Lamb |
| 07/01/05 | B & K (MUELLER) INDUSTRIES, INC. 2600 Elmhurst Road Elk Grove, IL 60007 | ¾" and 1" IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle ¾" – 107-824 T 1" – 107-825 T | R. Lamb |

NOTE: