



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**  
for  
**FLANGED DUCTILE IRON PIPE AWWA C115**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 04/01/03    **REVIEWED:** 10/01/13    **REVISED:** 10/01/13

**PREPARED BY:** Robert Lamb, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Water Pipe, Ductile Iron, Flanged, meeting AWWA C115, cement-mortar lined with asphalt seal coat, and asphalt coated, except when specified otherwise. Machined flange faces shall have a rust-preventative coating. Not for use in gravity wastewater applications.

<b>LISTING DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>	<b>APPROVAL</b>
04/01/03	FAST FABRICATORS, INC (formerly B & R Pipe Fabrication) 800 Burlington Road Saginaw, TX 76179	See notes below	R. Lamb
04/01/03	FOUNDRY SERVICES, INC. 4309 North 26 <sup>th</sup> Street Omaha, NE 68111	See notes below	R. Lamb
04/01/03	CUSTOM FAB (San Antonio facility) 109 Fifth Street Orlando, FL 32824	See notes below	R. Lamb
04/01/03	METRO-TEX FABRICATORS, INC. 5107 Brookglen Houston, TX 77017	See notes below	R. Lamb
04/01/03	U.S. PIPE & FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	See notes below	R. Lamb

**NOTE:**

1. Acceptable sizes are 4", 6", 8", 12", 16", 20", 24", 30", and multiples of 6" in larger sizes.
2. D.I. Pipe by U.S. manufacturer.
3. Certification required for testing of each joint to 300 psi minimum.
4. For pipe larger than 24" diameter, manufacturer must provide one of the following with project submittal: a) evidence of current ISO registration, b) evidence of current Austin Water Utility-approved quality control program, or c) name and qualifications of independent, third party firm that will test and inspect pipe produced for City of Austin, as per Standard Specification Item 510.