



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
FIBERGLASS PIPE FOR WASTEWATER

USING DEPARTMENT: Water Utility **ISSUED:** 04/01/92 **REVIEWED:** 01/01/14 **REVISED:** 01/01/14

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Pipe, Fiberglass, Cast Centrifugally or with Continuously Advancing Mandrel, for wastewater service, 24 inch through 96 inch diameter, Glass Fiber Reinforced Plastic Mortar Pipe made of thermosetting polyester resins, aggregates and fiberglass meeting the requirements of AWWA C950 and ASTM Standards as follows: D 3262 for Sewer Pipe having minimum stiffness of 72 lbf per inch of length per inch of deflection (psi), D 3840 for Fittings, D 4161 for Joints having elastomeric seals, and F 477 for Gaskets. Pipe shall have Cell Designation 111 or 123, PS 72 as defined by ASTM D 3262. This SPL does not apply to jacking pipe.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/96	HOBAS, USA, Inc. 1413 Richey Road Houston, TX 77073	Hobas Pipe (OD-controlled) ISO certified (see Note 2)	W. Flynn
07/01/12	US COMPOSITE PIPE SOUTH 18585 Samuels Rd. Zachary, LA 70791	Flowtite Pipe (ID-controlled) ISO certified (see Note 2)	R. Lamb

NOTE:

- For each project, Design Engineer shall submit to Austin Water Utility deflection calculations based upon actual installation conditions as required by Sec. 217 of TCEQ rules. Installations will be considered for approval on a case-by-case basis.
- For pipe larger than 24" diameter, manufacturer must provide one of the following with each **PROJECT SUBMITTAL**: a) evidence of **CURRENT** ISO registration, b) evidence that Austin Water Utility approved the manufacturer's quality control program prior to bidding project, or c) evidence that Austin Water Utility approved the manufacturer's independent, third party quality control firm prior to bidding project.
- Deflection testing is required and shall be conducted after final backfill has been in place at least 30 days. A rigid mandrel shall be used. Mandrel sizes are as follows:

Nominal Diameter, inches	95% Mandrel Diameter, inches	
	OD-Controlled Pipe	ID-Controlled Pipe
24	23.25	23.53
30	28.88	29.22
36	34.60	34.99
42	40.25	40.64
48	45.97	46.41
54	51.69	52.61
60	56.96	56.34
72	68.31	66.25
78	73.96	73.61
84	78.87	80.96
90	85.50	N/A
96	90.22	88.32