



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**
for
STRUCTURAL LINING FOR WASTEWATER MANHOLES

USING DEPARTMENT: Water Utility **ISSUED:** 10/03/94 **REVIEWED:** 01/01/08 **REVISED:** 01/01/08

PREPARED BY: Bill Flynn, P.E./David Rinn **CITY STOCK NUMBER:**

DESCRIPTION: Structural Lining, cementitious, corrosion-resistant, for lining existing wastewater manholes. Linings shall have 1" minimum thickness, and finished surfaces shall conform to the original configuration of the manhole. Preparation and application shall be in strict accordance with manufacturer's recommendations.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/1/00	STRONG SEAL SYSTEMS P.O. Box 9209 Pine Bluff, AR 71611	Strong-Seal High Performance Mix-Calcium Aluminates, or Strong-Seal MS2C	W. Flynn
10/1/97	QUADEX, INC. P.O. Box 657 Cabot, AR 72023	Quadex <u>Aluminaliner</u> (See description above for minimum thickness)	W. Flynn
01/02/97	KERNEOS, INC. 1316 Priority Lane Chesapeake, VA 23324	SewperCoat - P.G. - Pumpable Grade - 2000 HS - Gunnite Grade (See description above for minimum thickness)	W. Flynn

NOTE:

1. For manholes in which the pH may be 2.0 or less, an additional liner as listed in SPL WW-511 may be required for complete corrosion protection.