



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for

CEMENTITIOUS LINING FOR WASTEWATER MANHOLES

USING DEPARTMENT: Water Utility **ISSUED:** 01/01/08 **REVIEWED:** 04/01/08 **REVISED:** 04/01/08

PREPARED BY: Robert Lamb, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Lining, cementitious material, corrosion resistant, spray or brush applied. Thickness shall be between 1/4 inch and 1/2 inch. Substrate surface shall be prepared by sand blasting.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/01/08	KERNEOS, INC. 1316 Priority Lane Chesapeake, VA 23324	SewperCoat 2000 HS Regular (applied by high velocity, dry-gunite machine) SewperCoat PG (applied by low-pressure, wet-spray maching) Applicator: National Works	R. Lamb

NOTE:

1. Liner thickness shall be measured by the penetration method at locations specified by the City of Austin inspector prior to final setting of the material.
2. May be applied by brush only on surfaces where low-pressure, wet-spray or high-velocity, dry-gunite applications would be unsatisfactory, such as on manhole inverts.