



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
LININGS FOR DUCTILE IRON WASTEWATER PIPE**

USING DEPARTMENT: Water Utility **ISSUED:** 04/01/96 **REVIEWED:** 01/01/08 **REVISED:** 01/01/08

PREPARED BY: Bill Flynn **CITY STOCK NUMBER:**

DESCRIPTION: Corrosion Resistant Linings for Ductile Iron Wastewater Pipe and Fittings: Pipe Meeting AWWA C151, Fittings Meeting AWWA C110 or C153 and requirements of SPL WW-602 or SPL WW-27B. Pipe or fitting manufacturer remains fully responsible for satisfactory performance of the lined wastewater pipe and fittings.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/96	MADISON CHEMICAL INDUSTRIES INC. 490 McGreachie Drive Milton, Ontario L9T 3Y5	Corropipe II Wasteliner or Polythane Polyurethane Lining	W. Flynn
04/01/96	INDURON PROTECTIVE COATINGS c/o Vulcan Painters, Inc. Bessemer, AL 35021	Protecto 401 Epoxy Lining Ceramic	W. Flynn
04/03/00	SUPERIOR ENVIR. PRODUCTS c/o Fast Fabricators, Inc. (formerly B & R Pipe Fabrication) 800 Burlington Road Saginaw, TX 76179	SP-2000W	W. Flynn
04/01/96	KERNEOS, INC. 1316 Priority Lane Chesapeake, VA 23324	SewPerCoat	W. Flynn W. Flynn

NOTE:

1. Ductile Iron Force Main Pipe, except flanged pipe, to 12-inch diameter shall be Class 350; sizes 16-inch and larger shall be Class 250 minimum.
2. All flanged D.I. Pipe shall be special Class 53 meeting AWWA C115.
3. Materials shall meet applicable specification requirements. Acceptable pipe sizes are 4" through 12" diameter, and all larger D.I. Pipe sizes.
4. Type and brand of lining shall be marked on each pipe or fitting.
5. Only one type and brand of lining shall be used for fittings on a project.
6. Only one type and brand of lining shall be used for pipe on a project.