



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
MISCELLANEOUS GRAY IRON CASTINGS**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** Bill Flynn, P.E.      **ISSUED:** 05/10/84  
**REVISED BY:** Jeff A. Kyle, P.E.      **REVISED:** 01/01/19

**DESCRIPTION:** Gray Iron Castings, ASTM A48 Class 30B minimum, for valve boxes and bases, and other municipal construction castings as ordered.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/97	EJ (formerly East Jordan Iron Works) 216 East 6 <sup>th</sup> Street San Angelo, TX 76903	Includes water valve box 33470900 and square lid 33170901 for reclaimed water See note below	W. Flynn J. Kyle
11/08/01	CALCUTTA FOUNDRY, LTD SIGMA CORP. P.O. Box 300 Cream Ridge, NJ 08514	See note below	K. Flowers J. Kyle
01/02/04	PLPL FOUNDRY (INDIA) STAR PIPE PRODUCTS 4018 Westhollow Pkwy. Houston, TX 77082	Water Valve Box base, cover, and paving ring	R. Lamb
10/01/04	VICTORY IRON WORKS, LTD (INDIA) ACCUCAST 415 South 21 <sup>st</sup> Avenue Waco, TX 76706	Water Valve Box base and C-3 and C-7 covers	R. Lamb

**NOTES:**

- Must be in compliance with above description with City of Austin Standard Details and construction specifications. Machined surfaces shall be true to dimensions shown; no principal dimensions shall vary by more than 1/8" from dimension given on Standard Detail. Rocking or interference in fit between interchanged frame and covers is unacceptable.

**LATEST REVISIONS:**

- Removed following from SPL:
  - EJ and Sigma wastewater cleanout frames and covers
  - Accucast wastewater cleanout base